From: Kevin.Beer <[redacted]
Sent: 27 October 2026 16:09
To: Matthew.Porter <[redacted]>
Subject: DISC/26/0312 - Old Clayton Kennels

Dear Matthew,

Thank you for consulting Environmental Health on the above application.

We have reviewed the Ian Sharland Ltd Acoustic Assessment, dated 20th October 2026, and we have the following to make:

1. The fact that an updated noise survey has been provided is welcomed.
2. However, our interpretation of the noise assessment is that it only provides detail on the noise assessment and provides recommendations for mitigation, in our view it doesn't provide formal confirmation on what measures will be installed to ensure acceptable levels of internal noise will be achieved and what mechanical ventilation will be installed to prevent overheating and maintain thermal comfort i.e. it doesn't constitute a scheme for protecting the proposed development from noise as required by condition 16.
3. The above mentioned scheme will also need to formally confirm the height, density and location of the acoustic fencing.

Given the above unfortunately we are not able to recommend the discharge of condition 16 at this time.

Kind regards

Kevin

Kevin Beer
Environmental Protection Officer (Pollution)

Telephone: [redacted]
Email: [redacted]

Horsham District Council


LANDLORDS
GET ON TOP OF THE
RENTING
CHANGES
Renting is changing
UK Government
Get on top of the renting changes
New rights and responsibilities for landlords in England.
Click here to learn more...