[redacted] [redacted]g
Sent: 16 October 2024 15:00
[redacted] [redacted]
Subject: FW: Planning Application Consultation - DC/24/1199 Tanbridge House School Guildford Road Horsham

[redacted]
Sent: 04 October 2024 15:43
[redacted]
Subject: FW: Planning Application Consultation - DC/24/1199 Tanbridge House School Guildford Road Horsham

Hi Jacques

Thanks for the consultation request regarding the "Removal of outdated heating boilers, pumps, pipework controls and flue. Installation of new energy efficient boilers, pumps, pipework and controls including new flue."

There are no EH planning concerns but please can you advise the applicant that if the new plant burns at a rate equivalent to 366.4 kW that chimney height approval may be required under the Clean Air Act 1993. They can contact me or Thais to discuss.

Regards

Lee

Lee Money
Team Leader Environmental Protection
[redacted]