RE: HRA/24/0010 Hillybarn land at 523111 138231 The Mount Ifield

Wed 16/10/2024 15:00

Hi Steve

Thanks for the email and the copy of the updated Water Neutrality Report and Water Management Plan.

Generally I am happy with the supply arrangements. However for the avoidance of doubt please would the applicant provide a drawing showing the layout of the system and specifically how the three rainwater stage tanks will supply the 5 properties. Also please would the applicant provide further details of the first flush filter(s) to be installed.

As a shared distribution system is to be used, the water supply will require registration and inspection as set out in the private water supply regulations and DWI Technical Guidance .

Regards

Lee

Lee Money
Team Leader Environmental Protection

Telephone: 01403 215410 | 07879 481032
Email: Lee.Money@horsham.gov.uk



