HORSHAM DISTRICT COUNCIL CONSULTATION

TO:	Horsham District Council – Planning Dept
LOCATION:	62 High Street Steyning
DESCRIPTION:	
REFERENCE:	DC/24/0851
RECOMMENDATION:	~~Advice /~~ No Objection ~~/ Objection / More Information / Modification / Refusal~~
SUMMARY OF COMMENTS & RECOMMENDATION:	
MAIN COMMENTS: Dear Steve, I am content the proposed handrails will not harm the special interest of the listed building. My only request is further details of the fixing to the building. It may be necessary to fix through the panelling to the brickwork. Details can be provided by condition. Regards, Seán	

ANY RECOMMENDED CONDITIONS:

LB07 Submission of Details

Pre-Commencement Condition: No relevant works shall commence until the following details have been submitted to and approved in writing by the Local Planning Authority. The works must not be executed other than in complete accordance with these approved details:

Method statement fully describing the means of securing the handrails to the building. Including details of any alteration to the timber panelling.

Reason: As this matter is fundamental to ensure that the significance of the designated heritage asset, and the character, appearance and integrity of the building, is not prejudiced, thereby preserving the special architectural or historic interest which it possesses, and to comply with Policy 34 of the Horsham District Planning Framework (2015).

NAME:	Seán Rix
DEPARTMENT:	Conservation
DATE:	21.06.24