From: Sean.Rix
Sent: 16 July 2025 11:46
To: Meg.Bayliss; Planning
Subject: DC/25/1021 Goose Green Farm, Broadbridge Heath Road, Warnham

Categories: Consultations

Dear Meg,

I am satisfied the proposed building will not harm the setting of the principal, listed building. However, it will be necessary to provide the building with an appropriate roof covering. Mineral felt is not appropriate in this context as it is a ubiquitous material associated with garden sheds. I suggest a natural slate or timber shingles at this roof pitch. Please ask the applicant to confirm the use of a different roof covering before determining the application.

Regards,
Seán

Seán Rix
Senior Conservation Officer
Specialists Team - Strategic Planning
[redacted]

Horsham District Council

Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton