

RE: DC/26/0680: 2 Chene Colline Chase, 87 Lower Street, Pulborough - Installation of an Air Source Heat Pump.

Fri 15/05/2026 13:27

The submitted information shows the installation will fail the MCS020 noise assessment for air source heat pumps.

This can be addressed by ensuring the heat pump is better screened. I would suggest the existing trellis fence panel is replaced by a 2m high imperforate screen such as a close boarded fence panel.

Regards

Lee

Team Leader Pollution



Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

A banner from the UK Government titled "Renting is changing". On the left, there is a 3D illustration of a house with the text "LANDLORDS GET ON TOP OF THE RENTING CHANGES" on its side. In the center, there is a house icon and the text "Renting is changing" in a script font, with the UK Government crest and "UK Government" below it. On the right, a dark green box contains the text "Get on top of the renting changes", "New rights and responsibilities for landlords in England.", and "Click here to learn more...".