From: Kevin.Beer <Kevin.Beer@horsham.gov.uk>
Sent: 17 July 2024 16:05:43 UTC+01:00
To: "Nicola.Pettifer" <Nicola.Pettifer@horsham.gov.uk>
Subject: RE: DC/24/0054 - Land West of Kent Street, Cowfold

Dear Nicola,

Environmental Health have reviewed the Inacoustic Technical Note and we have the following comments to make.

1. The comments made in relation to the proposed battery and inverters are welcomed. We are however concerned with all the proposed noise source on the application site, not just those associated with the battery and inverters.
2. With the above in mind it is not clear what other ancillary equipment, cooling systems etc will be installed and how they will be delivered to ensure that there are no noise impacts to residential amenity. Further detailed commentary on this is required.
3. In our view further information is required before this application can be properly determined.

Kind regards

Kevin

Kevin Beer

Environmental Protection Officer

Telephone: 01403 215420
Email: Kevin.Beer@horsham.gov.uk



