[redacted]

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 14 February 2025 14:23
To: Planning
Subject: Planning consultation - DC/24/1512 Tesla Engineering Ltd Water Lane Storrington West Sussex RH20 3EA

Categories: Consultations

FAO: Shazia Penne

Dear Shazia,

Having viewed the details for Planning application No. DC/25/1512 for the demolition of existing storage buildings (Unit 5 and Unit 6), telecom communication mast and compound. Erection of a replacement storage building and creation of associated parking; evidence is required to show Fire Service vehicle access meets with the requirements identified in Approved Document B Volume 2: B5 Section 15, including Table 15.2 and diagram 15.3.

Regards

Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
[redacted]
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.