
From: FRS Water and Access [REDACTED]
Sent: 06 May 2025 09:35
To: Planning
Subject: Planning consultation - DC/25/0568 Chase Farm Shaws Lane Southwater West Sussex RH13 9BX

Categories: Consultations

FAO: Kate Turner

Dear Kate,

Having viewed the plans for the planning application no. DC/25/0568 for the change of use of part of a field and farmyard for four camping pods and one spa treatment pod (Retrospective): the nearest fire hydrant for the supply of water for firefighting is 295-metres away, 115-metres further than the 175-metre distance required for a domestic premises. If an alternative water supply for firefighting is to be considered it will need to conform with the details identified in Approved Document-B (AD-B) Volume 1: B5 section 14 and agreed with West Sussex Fire & Rescue Service.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 [REDACTED]

Web www.westsussex.gov.uk/fire

[REDACTED]
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his

[Click here to find out why we use pronouns in our signatures](#)



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
