



Horsham District Council,
Parkside,
Horsham,
West Sussex
RH12 1RL

Your ref
DC/26/0504

Our ref
DSA000052688

Date
5th April 2026

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Conversion of a disused agricultural building to a single dwellinghouse with associated residential curtilage.

Site address: Black Cherry Farm Bashurst Hill Itchingfield West Sussex RH13 0PB

Insufficient Information provided:

Condition:

Construction of the development shall not commence until details of the proposed means of foul drainage disposal have been submitted to and approved in writing by the Local Planning Authority in consultation with Southern Water.

Proposed soakaways:

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development. No new soakaways should be located within 5 metres of a public or adoptable gravity sewer, rising main or water main.

No Soakaways should be connected to the public surface water sewer.




For further advice, please contact Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at:
SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team southernwater.co.uk/developing-building/planning-your-development



© Crown copyright and database rights 2025 Ordnance Survey AC0000808122
© Local Government Information House Limited copyright and database rights 2025 AC0000808122

Controllable Valve			Flow Control			Inlet-Outfall	
Damboards	Penstock	Valve	Anti Flood Device	Pumped Anti Flood Device	Reflux Valve	Inlet	Outfall
Manhole							
BIF Bifurcation	Cascade	CP Catchpit	Head Of Public Sewer	IC Interceptor Chamber	Manhole	S Soakaway	WO Washout
Outfall Headworks		Overflow Chamber		Pipe Bridge		Pumping Station	
Outfall Headworks	CSO Combined Sewer Overflow	EMO Emergency Overflow	Emergency Overflow	Pipe Bridge	Micro Pumping Station	Pumping Station	
Sewer Level Monitor		Storage		Treatment Works		Weir	
Sewer Level Monitor	Storm Tank	Tidal Storage Tank		Treatment Works		Weir	Wastewater Site
Wastewater Pipe				Wastewater Use		Developer Services	
Culverted Water Course	Syphon	Foul	Combined	Sludge	Treated Effluent	Surface Water	Private
Drain	Tank Sewer	Trunk Sewer	Vacuum Main	Decommissioned Pipe	Build Over Agreement	Section 104	
Outfall	Overflow	Rising Main	Sewer		Catchment	Sub-Catchment	

Map Title: SW Print

Printed By: Isaac.Vowles
Date Printed: 07/04/2026
Map Scale: 1250

The information provided is believed to be correct but is provided on an 'as is' basis and without any warranty or condition express or implied, statutory or otherwise as to its quality or fitness for purpose. Actual positions of assets should always be determined on site.

