MEMORANDUM TO PUBLIC HEALTH AND LICENSING – PLANNING CONSULTATION

Application No: DC/25/0124

Case Officer: Jacques Burrowes

Address: Little Millfields Horsham Road Rowhook
Proposal: Prior Notification for Change of Use of former stable building to 1no. dwellinghouse with associated replacement wall cladding, roofing material, windows, doors and rainwater goods.

Date comments required by: 02/04/25

Details of the application can be viewed at https://www.horsham.gov.uk/planning/planning-applications/view-and-comment-on-planning-applications

Planning History:

Comments of Case Officer:

Specific areas that PHLO are asked to comment on:

Initial view of Case Officer:

PHLO Comments:

Commercial or agricultural buildings can be subject to significant contamination risks arising from their use, construction and storage of machinery equipment fuels or other chemicals. Potentially hazardous materials may also be incorporated in made ground, yards and hard standings. The presence of suspected corrugated asbestos cement roofing is noted in the structural report

In accordance with the recommendations of the Planning Practice Guidance, information is required on these matters and and a preliminary risk assessment including a site walkover should be provided to ensure the site can be made safe and suitable for the development.

Information with respect to water neutrality is also required.

Lee Money
Team Leader Environmental Protection 25/03/25