From: John.Griffiths
Sent: 25 June 2025 12:00
To: Planning
Subject: Your Ref: DC/25/0393; RE:

Categories: Consultations

Dear Planning,

I write further to the above consultation and the submission of additional information in relation to the premises' proposed commercial kitchen extract-ventilation system.

The system as now proposed – PoS grease filter, Pre-filter/Esp, UV Ozone – appears to be appropriate for the development, although it is strongly recommended that updated drawing of the layout of new system is submitted for consideration, to ensure that the plant and treatment components can physically be accommodated in the duct/stack run; are appropriately arranged to benefit abatement effectiveness and offer protection to the mechanical plant; and allow Condition to applied to ensure that the system is installed as agreed, should the application be Permitted.

If there is anything in this email that you do not understand, or if you have any other questions or queries, please do not hesitate to contact this Service or myself directly.

Kind regards.

Johno

John Griffiths
Area Environmental Health Officer

[redacted]

Horsham District Council