From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 28 May 2024 14:31
To: Planning
Subject: Planning consultation - DC/23/2103 Hilland Farm Hilland Road Billingshurst West Sussex RH14 9HN

Categories: Consultations

FAO: Nicola Pettifer

Dear Nicola,

Having viewed the plans for the planning application no. DC/23/2103 for the erection of Business Park following demolition of existing redundant farm buildings, the nearest fire hydrant to this site is 160 metres away 70 metres further than the 90 metres distance required for a commercial premises. If an alternative supply of water for firefighting is to be considered it will need to conform with the details identified in Approved Document – B (AD-B) Volume 2 - 2019 edition: B5 section 16.

Regards

Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
[redacted]
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.