From: Nicola.Mason <Nicola.Mason@horsham.gov.uk>
Sent: 19 September 2025 10:28:30 UTC+01:00
To: "Halima.Chowdhury" <Halima.Chowdhury@horsham.gov.uk>
Subject: DISC/25/0229 - Chantry Mill

Dear Halima

I am satisfied with the information submitted but would have the following comments:

- The preference would be for slimline double glazing which are usually 14mm thick or less, the proposed windows are 15mm. I would not raise an objection but would ask if the thinner windows has been considered.
- In terms of the insulation to the roof I note the drawings show the eaves to be ventilated by either a continuous 25mm gap or through a proprietary under tile ventilator and either ventilated ridge tiles or venting tiles to match roof tiles in colour as much as possible. Once this has been decided please could the detail be confirmed. The gutters and rain water goods should not be plastic but either cast iron or cast aluminium or cast effect plastic.

Kind regards

Nicola

Nicola Mason

Conservation Officer
Specialists Team - Strategic Planning

Telephone: 01403 215289
Email: Nicola.Mason@horsham.gov.uk

Horsham District Council