

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 27 January 2026 12:57
To: Planning
Subject: Planning consultation - DC/25/2102 Kinsbrook Vineyard West Chiltington Road Thakeham Pulborough West Sussex RH20 2RZ

Categories: Consultations

FAO: Halima Chowdhury

Dear Halima,

Having viewed the details for planning application no. DC/25/2102 for the prior notification for a temporary campsite for two days a week from April 2026 to September 2026, for the site owners information , which I'm sure they are fully aware, the nearest a fire appliance will be capable of reaching is the Kinsbrook Vineyard hard standing area 260-metres away, so initial fire fighting equipment should be considered for the small 4 pitch camping area in case a fire incident occurs and potentially starts to spread in dry and parched conditions. The nearest fire hydrant to the fire hydrant location is another 250-metres away, so there would be no supply of water for firefighting should a fire incident occur.

Regards
Ian



Ian Stocks

Water & Access Manager - Protection

West Sussex Fire & Rescue Service

Office 0330 222 4499 **Mobile** [REDACTED]


Web www.westsussex.gov.uk/fire

Email frs.waterandaccess@westsussex.gov.uk

Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his

[Click here to find out why we use pronouns in our signatures](#)



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
