

THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION. INSTALLATION DRAWINGS SHOULD BE PRODUCED BY THE CONTRACTOR AND AGREED WITH THE CLIENT TEAM PRIOR TO ANY INSTALLATION WORK

THIS DRAWING SHALL BE PRINTED IN COLOUR

AREA TO REMAIN UNTOUCHED

BUILDING 13

BUILDING 13

BUILDING 14


BUILDING 16

BLOCK 07
PARTIALLY
DEMOLISHED

BUILDING 15

BLOCK 10

PRE CURFEW: ALL
LUMINAIRES ON (FOR SITE)

LUMINAIRE SCHEDULE	
REF	TYPE OF LUMINAIRE
L1 	WALL MOUNTED LUMINAIRE
L2 	POLE MOUNTED LUMINAIRE (AT 6m)
L3 	POLE MOUNTED LUMINAIRE (AT 3m)
L4 	CIRCULAR DOWNLIGHT LUMINAIRE (CANOPY)
L5 	CEILING MOUNTED LUMINAIRE (BIKE SHED AND BIN STORE)
L6 	FLOODLIGHT FOR PITCH LIGHTING (AT 12m)
L7 	FLOODLIGHT FOR MUGA LIGHTING (AT 10m)

Legend	
	1 LUX
	1.5 LUX
	2 LUX
	3 LUX
	5 LUX
	7.5 LUX
	10 LUX
	15 LUX
	20 LUX
	30 LUX
	50 LUX
	75 LUX
	100 LUX
	150 LUX
	200 LUX
	300 LUX
	400 LUX
	500 LUX

Notes:

- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS, SPECIFICATIONS, SCHEDULES AND BUILDING MODELS INCLUDING SCHEMATICS. THE CONTRACTOR SHALL REFER TO THE ARCHITECTS DRAWINGS FOR SETTING OUT DETAILS/DIMENSIONS.
- THE ELECTRICAL SERVICES INSTALLATIONS ARE DESIGNED TO COMPLY FULLY WITH THE BUILDING REGULATIONS STANDARDS, AND ARE DESIGNED IN ACCORDANCE WITH THE RECOMMENDATIONS OF THE CIBSE GUIDES, AS ISSUED BY THE CHARTERED INSTITUTION OF BUILDING SERVICES ENGINEERS.
- REFER TO THE ARCHITECTS DRAWINGS FOR DETAILS OF ALL BUILDING FIRE COMPARTMENTATION BARRIERS. ANY SERVICES PENETRATING THE FIRE COMPARTMENT SHALL BE FIRE SEALED USING THE APPROVED PENETRATION DETAIL.
- ALL PENETRATIONS THROUGH FIRE WALLS SHALL BE FIRE STOPPED TO MAINTAIN THE FIRE INTEGRITY OF THE FIRE WALL. ALL SLAB PENETRATIONS TO HAVE FIRE STOPPING TO MAINTAIN THE INTEGRITY OF THE FIRE RATED SLAB. THE CONTRACTOR SHALL MAKE GOOD ALL PENETRATIONS TO THE APPROVAL OF BUILDING CONTROL.
- THIS DRAWING SHALL NOT BE USED FOR INSTALLATION. THE ELECTRICAL SERVICES CONTRACTOR SHALL BE RESPONSIBLE FOR PRODUCTION OF COORDINATED INSTALLATION DRAWINGS CHECKED WITH ACTUAL SITE DIMENSIONS.
- ALL DIMENSIONS WHERE INDICATED ARE IN MILLIMETRES UNLESS STATED OTHERWISE. ALL DIMENSIONS SHALL BE CHECKED ON SITE PRIOR TO COMMENCEMENT OF ANY WORKS.
- ALL CABLES TO BE WITHIN VOIDS UNLESS OTHERWISE STATED.
- THE EMERGENCY LIGHTING SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH BS5266 PART 1.
- SIGNAGE SHALL BE TO BS5499 PART 4.

P03	01.07.26	ARG	MXA	BXP	Legend updated
P02	26.06.26	ARG	MXA	BXP	All-weather pitch updated to 350lux for hockey
P01	02.02.26	MLS	MXA	BXP	STAGE 3 ISSUE

Rev	Date	By	Chk	Apv'd	Description
-----	------	----	-----	-------	-------------

PROJECT
Steyning Grammar School
Steyning

CLIENT



www.methodplp.com Swindon Tel: 01793 822044

DRAWING TITLE
External Lighting Layout
Pre Curfew

DEIR REF 085		STAGE 3 (PLANNING)		
DATE	SCALE	DRAWN BY	CHK BY	APV'D BY
02.02.2026	1:500 - A1	MLS	MXA	BXP
DRAWING NUMBER	SRP1121-MET-ZZ-EX-D-E-6350			REVISION NO.
				S2 - P03

Scaling Note: Do NOT scale from this drawing.

File Location: V:\Projects\Education\2672630-Steyning Grammar School\B01\1 - CAD\B3 - Lighting\SRP1121-MET-ZZ-EX-D-E-6350-S2-P03_ExternalLightingLayout\PreCurfew\B03.dwg

