

- ## BULK METER ARRANGEMENT

MINIMUM 10x DI UPSTREAM OF BULK METER
MINIMUM 5x DI DOWNSTREAM OF BULK METER

[illegible]