



LUMINAIRE SCHEDULE	
REF	TYPE OF LUMINAIRE
L1 	WALL MOUNTED LUMINAIRE
L2 	POLE MOUNTED LUMINAIRE (AT 6m)
L3 	POLE MOUNTED LUMINAIRE (AT 3m)
L4 	CIRCULAR DOWNLIGHT LUMINAIRE (GRANDP)
L5 	CEILING MOUNTED LUMINAIRE (BARE SHED AND BIN STORE)
L6 	FLOODLIGHT FOR PITCH LIGHTING (AT 12m)
L7 	FLOODLIGHT FOR WILGA LIGHTING (AT 10m)

Legend	
	1 LUX
	1.5 LUX
	2 LUX
	3 LUX
	5 LUX
	7.5 LUX
	10 LUX
	15 LUX
	20 LUX
	30 LUX
	50 LUX
	75 LUX
	100 LUX
	150 LUX
	200 LUX
	300 LUX
	500 LUX

1. THE DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS, SPECIFICATIONS, SCHEDULES AND BUILDING MODEL INFORMATION.
2. THE ELECTRICAL SERVICE INSTALLATION ARE DESIGNED TO COMPLY WITH THE NATIONAL ELECTRICAL CODE (NEC) AND THE REQUIREMENTS OF THE CURRICULUM, AS ISSUED BY THE CHARTERED INSTITUTION OF BUILDING ENGINEERS.
3. THE ELECTRICAL INSTALLATION SHALL BE DESIGNED TO PROVIDE THE APPROPRIATE NUMBER OF CIRCUITS, CIRCUIT BREAKERS, AND CONDUITS TO SERVE THE ELECTRICAL LOADS OF THE BUILDING.
4. PENETRATIONS THROUGH THE WALL SHALL BE STOPPED TO PREVENT WEATHER AND PESTS FROM ENTERING THE BUILDING. PENETRATIONS TO HAVE THE NECESSITY TO MAINTAIN THE INTEGRITY OF THE WALL DATA, THE CONTRACTOR SHALL MAKE GOOD ALL PENETRATIONS TO BE THE APPROVAL OF BUILDING CONTROL.
5. THE DRAWING SHALL NOT BE USED FOR INSTALLATION, OF THE ELECTRICAL INSTALLATION, WITHOUT THE APPROVAL OF THE CHARTERED INSTITUTION OF BUILDING ENGINEERS.
6. ALL DIMENSIONS WHERE INDICATED ARE IN MILLIMETERS UNLESS STATED OTHERWISE. ALL DIMENSION SHALL BE CHECKED ON SITE PRIOR TO COMMENCEMENT OF ANY WORKS.
7. ALL CABLES OR WIRING UNLESS OTHERWISE STATED.
8. THE EMERGENCY LIGHTING SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH BS5268 PART 1.
9. SIGNAGE SHALL BE TO BS5299 PART 1.