Heat Geek Installations Ltd.

63 Bermondsey Street, London, SE1 3XF

MCS: IAA-10057
RECC: 00075650
Trustmark: 3147435

MCS 020 Noise Assessment Results

Homeowner Details	
Customer	**Ian Cutting**
Installation address	**87 Morris Drive, Billingshurst, RH14 9ST**

Installation Details	
ASHP	Vaillant aroTHERM plus 5kW
Installation address	**87 Morris Drive, Billingshurst, RH14 9ST**

Assessment Details	
Date Created	9th Apr 2024
Assessment Zone	Assessment position1
Heat Pump Sound Power Level	54dB(A)
Noise Barrier	None
Directivity	4Q
Distance to Assessment position	20m
Calculated noise level	40.1dB(A)
Deemed Pass MCS020	Yes

For any queries regarding this information, please get in touch with us at upgrades@heatgeek.com or 0808 168 9403