

KITCHEN VENTILATION MAINTENANCE SCHEDULE

CANOPY GREASE FILTERS

Clean in dishwasher once every week minimum,

DUCTWORK, CANOPY, FANS AND ATTENUATORS

Specialist contractor clean once a year. All cleaning doors etc are to be incorporated into the proposed new systems.

ESP 3000 AW UNITS

An ESP auto wash system is proposed as an optional extra to clean the 2 No. ESP 3000 AW Units. This system will be programme to clean every 24 hours.

Every month the mesh filters will need to be checked and every 3 months a full inspection of the unit will be required.

Should the auto wash system not be incorporated the unit should be manually cleaned internally once a week.

No monthly maintenance is required for the UV-0-500 but an inspection of correct operation should be carried out on a 6-8 week basis.