Horsham District Council

DELEGATED APPLICATIONS - ASSESSMENT SHEET

APPLICATION NO./ADDRESS:
DC/24/0297
Highcroft Farmhouse, Gay Street, Pulborough, West Sussex, RH20 2HJ

DESCRIPTION:
To dismantle and replace 4 spans of low voltage overhead lines between poles 562798 and 551763. To decommission and remove the existing 25 KVA pole mounted transformer (pmt) off of pole 562798 and replace with a new 50KVA pmt. To install a new stay wire on pole 562798. To install new LV earth cable as shown on the plan. To install a new stay wire on pole 551761. To install 2 new stay wires on pole 551763. To install a new underground service cable to Highcroft Farmhouse.

REPRESENTATIONS AND CONSULTATIONS RESPONSES
None

PLANNING ASSESSMENT
The Local Planning Authority is asked to determine if the proposal would, in the opinion of that authority, have a significant adverse effect on the environment.

It is considered that the nature and siting of the proposal works would not have any significant adverse effect upon the environment. Therefore, it is recommended that there is no objection to the proposal.

Recommendation: NO OBJECT Overhead Line

DELEGATED

Authorising Officer sign/initial Guy Everest Date: 19.03.2024