RE: DC/25/0043 Roseland Blackgate Lane Henfield West Sussex BN5 9HA - EH response

Fri 07/03/2025 17:18

Thanks for the consultation request.

The ASHP is a relatively quiet unit but locating on the side of the building close to the neighbouring dwelling is not ideal as this may cause additional noise reflections which are hard to predict. I would prefer the unit to be relocated If there is scope for that.

Have a good weekend

Lee

Lee Money
Team Leader Pollution

Telephone: 01403 215410 | 07879 481032
Email: Lee.Money@horsham.gov.uk

PLEASE NOTE: We have moved, please see the new Council address below.
Horsham District Council, Albery House, Springfield Road, Horsham, West Sussex RH12 2GB
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton