

19 October 2023

Giles Holbrook
Development Section
Horsham District Council
Parkside, Chart Way,
Horsham
West Sussex RH12 1RL

Dear Giles

Re: Planning Application No: DC/23/1787 – Reserved matters in relation to DC/15/2813 relating to the construction of 280 dwellings with associated works at Sub Phase 3DEFG, Kilnwood Vale, Crawley Road, Horsham

Our Ref: LGW5326

Thank you for your email/letter dated 06 October 2023, regarding the above-mentioned consultation.

The proposed development has been examined from an aerodrome safeguarding perspective and does not conflict with safeguarding criteria. We therefore have no objection to this proposal.

We would, however, make the following observation:

Cranes

Given the nature of the proposed development it is possible that a crane may be required during its construction. We would, therefore, draw the applicant's attention to the requirement within the British Standard Code of Practice for the safe use of Cranes, for crane operators to consult the aerodrome before erecting a crane in close proximity to an aerodrome. London Gatwick requires a minimum of four weeks notice. For crane queries/applications please visit [Crane Permits \(gatwickairport.com\)](https://www.gatwickairport.com/crane-permits) or email cranes@gatwickairport.com

If you have any queries, please do not hesitate to contact me.

Yours sincerely

Amanda Purdye, Aerodrome Safeguarding Officer
For and on behalf of London Gatwick
Email: gal.safeguarding@gatwickairport.com