[redacted]

Sent: 02 December 2024 17:17
To: Planning
Subject: Planning consultation - DC/24/1179 Trueloves Field Marches Road Kingsfold West Sussex

Categories: Consultations

FAO: Shazia Penne

Dear Shazia,

Having viewed the plans for the planning application no DC/24/1179 for the erection of a stable building, sand school and change of use of land for private equine use.; the nearest fire hydrant for the supply of water for firefighting to proposed stable building is 270 metres away, 180-metres further than the 90-metre distance required for a commercial premises. If an alternative water supply for firefighting is to be considered it will need to conform with the details identified in Approved Document–B (AD-B) Volume 2: B5 section 16 and agreed with West Sussex Fire & Rescue Service.

Regards

Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
Office 0330 222 4499 [redacted]
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.