[redacted]

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 09 February 2024 13:29
To: Planning
Subject: Planning consultation - DC/23/0331 Land Parcel at 523528 121673 Lot 2 Kent Street Cowfold West Sussex

Categories: Consultations

FAO: Kate Turner

Dear Kate,

Having viewed the plans for the planning application no. DC/23/0331 for the temporary stationing of a caravan/mobile home to allow for 'living on site' during the course of construction of new housing on an adjoining site, the nearest fire hydrant for the supply of water for firefighting is 735 metres away, 560 metres further than the 175-metre distance required for a domestic premises. If an alternative supply of water for firefighting is to be considered it will need to conform with the details identified in Approved Document–B (AD-B) Volume 1: B5 section 14.

Regards

Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
[redacted]
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.