

Plot	Room	Schedule
Plot 001 - 356 - West	Bedroom1	-
Plot 001 - 356 - West	Bedroom2	Noise - 0.15 EA
Plot 001 - 356 - West	Bedroom3	Noise - 0.15 EA
Plot 001 - 356 - West	Kitchen	-
Plot 001 - 356 - West	Living	-
Plot 002 - 356 - West	Bedroom1	-
Plot 002 - 356 - West	Bedroom2	Noise - 0.15 EA
Plot 002 - 356 - West	Bedroom3	Noise - 0.15 EA
Plot 002 - 356 - West	Kitchen	-
Plot 002 - 356 - West	Living	-
Plot 003 - 356 - West	Bedroom1	-
Plot 003 - 356 - West	Bedroom2	Noise - 0.15 EA
Plot 003 - 356 - West	Bedroom3	Noise - 0.15 EA
Plot 003 - 356 - West	Kitchen	-
Plot 003 - 356 - West	Living	-
Plot 004 - 356 - West	Bedroom1	-
Plot 004 - 356 - West	Bedroom2	Noise - 0.15 EA
Plot 004 - 356 - West	Bedroom3	Noise - 0.15 EA
Plot 004 - 356 - West	Kitchen	-
Plot 004 - 356 - West	Living	-
Plot 005 - 341 - West	Bedroom1	Noise - 0.1 EA
Plot 005 - 341 - West	Bedroom2	Noise - 0.1 EA
Plot 005 - 341 - West	Kitchen	-
Plot 005 - 341 - West	Living	-
Plot 006 - 341 - West	Bedroom1	Noise - 0.1 EA
Plot 006 - 341 - West	Bedroom2	Noise - 0.1 EA
Plot 006 - 341 - West	Kitchen	-
Plot 006 - 341 - West	Living	-
Plot 007 - 474 - North	Bedroom1	Noise - Restricted Openability
Plot 007 - 474 - North	Bedroom2	Noise - Closed Night
Plot 007 - 474 - North	Bedroom3	Noise - Closed Night
Plot 007 - 474 - North	Bedroom4	Noise - Restricted Openability
Plot 007 - 474 - North	Kitchen	-
Plot 007 - 474 - North	Living	-
Plot 008 - 474 - South	Bedroom1	Noise - Closed Night
Plot 008 - 474 - South	Bedroom2	Noise - Restricted Openability
Plot 008 - 474 - South	Bedroom3	Noise - Restricted Openability
Plot 008 - 474 - South	Bedroom4	Noise - Closed Night
Plot 008 - 474 - South	Kitchen	-
Plot 008 - 474 - South	Living	-
Plot 009 - 474 - South	Bedroom1	Noise - Restricted Openability
Plot 009 - 474 - South	Bedroom2	Noise - Restricted Openability
Plot 009 - 474 - South	Bedroom3	Noise - Restricted Openability
Plot 009 - 474 - South	Bedroom4	Noise - Restricted Openability
Plot 009 - 474 - South	Kitchen	-
Plot 009 - 474 - South	Living	-

Plot 010 - 356 - North	Bedroom1	Noise - 0.15 EA
Plot 010 - 356 - North	Bedroom2	Noise - Closed Night
Plot 010 - 356 - North	Bedroom3	Noise - Closed Night
Plot 010 - 356 - North	Kitchen	-
Plot 010 - 356 - North	Living	-
Plot 011 - 356 - North	Bedroom1	-
Plot 011 - 356 - North	Bedroom2	Noise - Closed Night
Plot 011 - 356 - North	Bedroom3	Noise - Closed Night
Plot 011 - 356 - North	Kitchen	-
Plot 011 - 356 - North	Living	-
Plot 012 - 356 - North	Bedroom1	-
Plot 012 - 356 - North	Bedroom2	Noise - 0.1 EA
Plot 012 - 356 - North	Bedroom3	Noise - 0.1 EA
Plot 012 - 356 - North	Kitchen	-
Plot 012 - 356 - North	Living	-
Plot 013 - 356 - North	Bedroom1	-
Plot 013 - 356 - North	Bedroom2	Noise - 0.1 EA
Plot 013 - 356 - North	Bedroom3	Noise - 0.1 EA
Plot 013 - 356 - North	Kitchen	-
Plot 013 - 356 - North	Living	-
Plot 014 - 474 - North	Bedroom1	-
Plot 014 - 474 - North	Bedroom2	Noise - Restricted Openability
Plot 014 - 474 - North	Bedroom3	Noise - Restricted Openability
Plot 014 - 474 - North	Bedroom4	-
Plot 014 - 474 - North	Kitchen	-
Plot 014 - 474 - North	Living	-
Plot 015 - 474 - North	Bedroom1	-
Plot 015 - 474 - North	Bedroom2	Noise - Restricted Openability
Plot 015 - 474 - North	Bedroom3	Noise - Restricted Openability
Plot 015 - 474 - North	Bedroom4	-
Plot 015 - 474 - North	Kitchen	-
Plot 015 - 474 - North	Living	-
Plot 016 - 474 - North	Bedroom1	-
Plot 016 - 474 - North	Bedroom2	Noise - Restricted Openability
Plot 016 - 474 - North	Bedroom3	Noise - Restricted Openability
Plot 016 - 474 - North	Bedroom4	-
Plot 016 - 474 - North	Kitchen	-
Plot 016 - 474 - North	Living	-
Plot 017 - 474 - South	Bedroom1	-
Plot 017 - 474 - South	Bedroom2	-
Plot 017 - 474 - South	Bedroom3	-
Plot 017 - 474 - South	Bedroom4	-
Plot 017 - 474 - South	Kitchen	-
Plot 017 - 474 - South	Living	-
Plot 018 - 474 - South	Bedroom1	-
Plot 018 - 474 - South	Bedroom2	-
Plot 018 - 474 - South	Bedroom3	-

Plot 018 - 474 - South	Bedroom4	-
Plot 018 - 474 - South	Kitchen	-
Plot 018 - 474 - South	Living	-
Plot 019 - 474 - South	Bedroom1	-
Plot 019 - 474 - South	Bedroom2	-
Plot 019 - 474 - South	Bedroom3	-
Plot 019 - 474 - South	Bedroom4	-
Plot 019 - 474 - South	Kitchen	-
Plot 019 - 474 - South	Living	-
Plot 020 - 356 - South	Bedroom1	-
Plot 020 - 356 - South	Bedroom2	-
Plot 020 - 356 - South	Bedroom3	-
Plot 020 - 356 - South	Kitchen	-
Plot 020 - 356 - South	Living	-
Plot 021 - 356 - South	Bedroom1	-
Plot 021 - 356 - South	Bedroom2	-
Plot 021 - 356 - South	Bedroom3	-
Plot 021 - 356 - South	Kitchen	-
Plot 021 - 356 - South	Living	-
Plot 022 - 474 - South	Bedroom1	-
Plot 022 - 474 - South	Bedroom2	Noise - Closed Night
Plot 022 - 474 - South	Bedroom3	Noise - Closed Night
Plot 022 - 474 - South	Bedroom4	Noise - Closed Night
Plot 022 - 474 - South	Kitchen	-
Plot 022 - 474 - South	Living	-
Plot 023 - 474 - South	Bedroom1	Noise - Restricted Openability
Plot 023 - 474 - South	Bedroom2	Noise - Restricted Openability
Plot 023 - 474 - South	Bedroom3	Noise - Restricted Openability
Plot 023 - 474 - South	Bedroom4	Noise - Restricted Openability
Plot 023 - 474 - South	Kitchen	-
Plot 023 - 474 - South	Living	-
Plot 024 - A01V2 - North	Bedroom1	Security - Closed Night
Plot 024 - A01V2 - North	KitchenLiving	-
Plot 025 - A03V2 - North	Bedroom1	Security - Closed Night
Plot 025 - A03V2 - North	KitchenLiving	-
Plot 026 - A02V2 - North	Bedroom1	Security - Closed Night
Plot 026 - A02V2 - North	Bedroom2	Security - Closed Night
Plot 026 - A02V2 - North	KitchenLiving	-
Plot 027 - A04V2 - North	Bedroom1	Noise - Closed Night
Plot 027 - A04V2 - North	KitchenLiving	-
Plot 028 - A05V2 - North	Bedroom1	Noise - 0.15 EA
Plot 028 - A05V2 - North	Bedroom2	Noise - 0.15 EA
Plot 028 - A05V2 - North	KitchenLiving	-
Plot 029 - A06V2 - North	Bedroom1	Noise - 0.1 EA
Plot 029 - A06V2 - North	Bedroom2	Noise - 0.1 EA
Plot 029 - A06V2 - North	KitchenLiving	-
Plot 030 - MAIV1 - North	Bedroom1	Security - Closed Night

Plot 030 - MAIV1 - North	KitchenLiving	-
Plot 031 - MAIV1 - North	Bedroom1	-
Plot 031 - MAIV1 - North	Bedroom2	-
Plot 031 - MAIV1 - North	KitchenLiving	-
Plot 032 - A01V1 - North	Bedroom1	Security - Closed Night
Plot 032 - A01V1 - North	KitchenLiving	-
Plot 033 - A03V1 - North	Bedroom1	Security - Closed Night
Plot 033 - A03V1 - North	KitchenLiving	-
Plot 034 - A02V1 - North	Bedroom1	Security - Closed Night
Plot 034 - A02V1 - North	Bedroom2	Security - Closed Night
Plot 034 - A02V1 - North	KitchenLiving	-
Plot 035 - A01V1 - North	Bedroom1	-
Plot 035 - A01V1 - North	KitchenLiving	-
Plot 036 - A04V1 - North	Bedroom1	-
Plot 036 - A04V1 - North	Bedroom2	-
Plot 036 - A04V1 - North	KitchenLiving	-
Plot 037 - A02V1 - North	Bedroom1	-
Plot 037 - A02V1 - North	Bedroom2	-
Plot 037 - A02V1 - North	KitchenLiving	-
Plot 038 - MAIV2 - East	Bedroom1	Security - Closed Night
Plot 038 - MAIV2 - East	KitchenLiving	-
Plot 039 - MAIV2 - East	Bedroom1	-
Plot 039 - MAIV2 - East	Bedroom2	-
Plot 039 - MAIV2 - East	KitchenLiving	-
Plot 040 - 236 - East	Bedroom1	Noise - 0.1 EA
Plot 040 - 236 - East	Bedroom2	Noise - 0.3 EA
Plot 040 - 236 - East	Kitchen	-
Plot 040 - 236 - East	Living	-
Plot 041 - 242 - South	Bedroom1	-
Plot 041 - 242 - South	Bedroom2	Noise - 0.1 EA
Plot 041 - 242 - South	Kitchen	-
Plot 041 - 242 - South	Living	-
Plot 042 - 352 - South	Bedroom1	-
Plot 042 - 352 - South	Bedroom2	Noise - 0.1 EA
Plot 042 - 352 - South	Bedroom3	-
Plot 042 - 352 - South	Kitchen	-
Plot 042 - 352 - South	Living	-
Plot 043 - 352 - South	Bedroom1	-
Plot 043 - 352 - South	Bedroom2	Noise - 0.1 EA
Plot 043 - 352 - South	Bedroom3	-
Plot 043 - 352 - South	Kitchen	-
Plot 043 - 352 - South	Living	-
Plot 044 - 242 - South	Bedroom1	-
Plot 044 - 242 - South	Bedroom2	Noise - 0.1 EA
Plot 044 - 242 - South	Kitchen	-
Plot 044 - 242 - South	Living	-
Plot 045 - 242 - South	Bedroom1	-

Plot 045 - 242 - South	Bedroom2	Noise - 0.1 EA
Plot 045 - 242 - South	Kitchen	-
Plot 045 - 242 - South	Living	-
Plot 046 - 242 - South	Bedroom1	-
Plot 046 - 242 - South	Bedroom2	Noise - 0.1 EA
Plot 046 - 242 - South	Kitchen	-
Plot 046 - 242 - South	Living	-
Plot 047 - 236 - West	Bedroom1	Noise - Closed Night
Plot 047 - 236 - West	Bedroom2	Noise - Closed Night
Plot 047 - 236 - West	Kitchen	-
Plot 047 - 236 - West	Living	-
Plot 048 - 352 - West	Bedroom1	-
Plot 048 - 352 - West	Bedroom2	Noise - Closed Night
Plot 048 - 352 - West	Bedroom3	-
Plot 048 - 352 - West	Kitchen	-
Plot 048 - 352 - West	Living	-
Plot 049 - 352 - West	Bedroom1	-
Plot 049 - 352 - West	Bedroom2	Noise - Closed Night
Plot 049 - 352 - West	Bedroom3	-
Plot 049 - 352 - West	Kitchen	-
Plot 049 - 352 - West	Living	-
Plot 050 - 241 - East	Bedroom1	-
Plot 050 - 241 - East	Bedroom2	Noise - 0.15 EA
Plot 050 - 241 - East	Kitchen	-
Plot 050 - 241 - East	Living	-
Plot 051 - 241 - East	Bedroom1	-
Plot 051 - 241 - East	Bedroom2	Noise - 0.1 EA
Plot 051 - 241 - East	Kitchen	-
Plot 051 - 241 - East	Living	-
Plot 052 - 241 - East	Bedroom1	-
Plot 052 - 241 - East	Bedroom2	Noise - Closed Night
Plot 052 - 241 - East	Kitchen	-
Plot 052 - 241 - East	Living	-
Plot 053 - 241 - East	Bedroom1	-
Plot 053 - 241 - East	Bedroom2	Noise - Closed Night
Plot 053 - 241 - East	Kitchen	-
Plot 053 - 241 - East	Living	-
Plot 054 - 341 - East	Bedroom1	Noise - 0.1 EA
Plot 054 - 341 - East	Bedroom2	-
Plot 054 - 341 - East	Kitchen	-
Plot 054 - 341 - East	Living	-
Plot 055 - 341 - East	Bedroom1	Noise - 0.1 EA
Plot 055 - 341 - East	Bedroom2	-
Plot 055 - 341 - East	Kitchen	-
Plot 055 - 341 - East	Living	-
Plot 056 - 354 - East	Bedroom1	Noise - Closed Night
Plot 056 - 354 - East	Bedroom2	Noise - Closed Night

Plot 056 - 354 - East	Bedroom3	Noise - 0.1 EA
Plot 056 - 354 - East	Kitchen	-
Plot 056 - 354 - East	Living	-
Plot 057 - 241 - North	Bedroom1	-
Plot 057 - 241 - North	Bedroom2	Noise - 0.1 EA
Plot 057 - 241 - North	Kitchen	-
Plot 057 - 241 - North	Living	-
Plot 058 - 341 - North	Bedroom1	Noise - 0.1 EA
Plot 058 - 341 - North	Bedroom2	-
Plot 058 - 341 - North	Kitchen	-
Plot 058 - 341 - North	Living	-
Plot 059 - 341 - North	Bedroom1	Noise - 0.1 EA
Plot 059 - 341 - North	Bedroom2	-
Plot 059 - 341 - North	Kitchen	-
Plot 059 - 341 - North	Living	-
Plot 060 - 341 - North	Bedroom1	Noise - 0.1 EA
Plot 060 - 341 - North	Bedroom2	-
Plot 060 - 341 - North	Kitchen	-
Plot 060 - 341 - North	Living	-
Plot 061 - 354 - West	Bedroom1	Noise - Closed Night
Plot 061 - 354 - West	Bedroom2	Noise - 0.1 EA
Plot 061 - 354 - West	Bedroom3	Noise - 0.2 EA
Plot 061 - 354 - West	Kitchen	-
Plot 061 - 354 - West	Living	-
Plot 066 - 352 - South	Bedroom1	-
Plot 066 - 352 - South	Bedroom2	-
Plot 066 - 352 - South	Bedroom3	-
Plot 066 - 352 - South	Kitchen	-
Plot 066 - 352 - South	Living	-
Plot 067 - 352 - South	Bedroom1	-
Plot 067 - 352 - South	Bedroom2	-
Plot 067 - 352 - South	Bedroom3	-
Plot 067 - 352 - South	Kitchen	-
Plot 067 - 352 - South	Living	-
Plot 068 - 352 - South	Bedroom1	-
Plot 068 - 352 - South	Bedroom2	-
Plot 068 - 352 - South	Bedroom3	-
Plot 068 - 352 - South	Kitchen	-
Plot 068 - 352 - South	Living	-
Plot 069 - 352 - South	Bedroom1	-
Plot 069 - 352 - South	Bedroom2	-
Plot 069 - 352 - South	Bedroom3	-
Plot 069 - 352 - South	Kitchen	-
Plot 069 - 352 - South	Living	-
Plot 070 - 354 - West	Bedroom1	Noise - Closed Night
Plot 070 - 354 - West	Bedroom2	Noise - Closed Night
Plot 070 - 354 - West	Bedroom3	Noise - Closed Night

Plot 070 - 354 - West	Kitchen	-
Plot 070 - 354 - West	Living	-
Plot 071 - 341 - North	Bedroom1	Noise - Closed Night
Plot 071 - 341 - North	Bedroom2	Noise - Closed Night
Plot 071 - 341 - North	Kitchen	-
Plot 071 - 341 - North	Living	-
Plot 072 - 361 - North	Bedroom1	Noise - Closed Night
Plot 072 - 361 - North	Bedroom2	Noise - 0.1 EA
Plot 072 - 361 - North	Bedroom3	Noise - Closed Night
Plot 072 - 361 - North	Kitchen	-
Plot 072 - 361 - North	Living	-
Plot 073 - 361 - North	Bedroom1	Noise - Closed Night
Plot 073 - 361 - North	Bedroom2	Noise - 0.1 EA
Plot 073 - 361 - North	Bedroom3	Noise - 0.1 EA
Plot 073 - 361 - North	Kitchen	-
Plot 073 - 361 - North	Living	-
Plot 074 - 354 - East	Bedroom1	Noise - Closed Night
Plot 074 - 354 - East	Bedroom2	Noise - 0.1 EA
Plot 074 - 354 - East	Bedroom3	Noise - 0.1 EA
Plot 074 - 354 - East	Kitchen	-
Plot 074 - 354 - East	Living	-
Plot 075 - 242 - East	Bedroom1	Noise - Closed Night
Plot 075 - 242 - East	Bedroom2	-
Plot 075 - 242 - East	Kitchen	-
Plot 075 - 242 - East	Living	-
Plot 076 - 242 - East	Bedroom1	Noise - Closed Night
Plot 076 - 242 - East	Bedroom2	-
Plot 076 - 242 - East	Kitchen	-
Plot 076 - 242 - East	Living	-
Plot 077 - 242 - East	Bedroom1	Noise - 0.1 EA
Plot 077 - 242 - East	Bedroom2	-
Plot 077 - 242 - East	Kitchen	-
Plot 077 - 242 - East	Living	-
Plot 078 - 242 - East	Bedroom1	Noise - 0.1 EA
Plot 078 - 242 - East	Bedroom2	-
Plot 078 - 242 - East	Kitchen	-
Plot 078 - 242 - East	Living	-
Plot 079 - 242 - South	Bedroom1	Noise - 0.15 EA
Plot 079 - 242 - South	Bedroom2	-
Plot 079 - 242 - South	Kitchen	-
Plot 079 - 242 - South	Living	-
Plot 080 - 242 - South	Bedroom1	Noise - 0.15 EA
Plot 080 - 242 - South	Bedroom2	Noise - 0.2 EA
Plot 080 - 242 - South	Kitchen	-
Plot 080 - 242 - South	Living	-
Plot 081 - 352 - South	Bedroom1	Noise - 0.15 EA
Plot 081 - 352 - South	Bedroom2	Noise - 0.2 EA

Plot 081 - 352 - South	Bedroom3	Noise - Closed Night
Plot 081 - 352 - South	Kitchen	-
Plot 081 - 352 - South	Living	-
Plot 082 - 352 - South	Bedroom1	Noise - Closed Night
Plot 082 - 352 - South	Bedroom2	Noise - 0.2 EA
Plot 082 - 352 - South	Bedroom3	Noise - Closed Night
Plot 082 - 352 - South	Kitchen	-
Plot 082 - 352 - South	Living	-
Plot 083 - 352 - South	Bedroom1	Noise - Closed Night
Plot 083 - 352 - South	Bedroom2	Noise - 0.3 EA
Plot 083 - 352 - South	Bedroom3	Noise - Closed Night
Plot 083 - 352 - South	Kitchen	-
Plot 083 - 352 - South	Living	-
Plot 084 - 352 - South	Bedroom1	Noise - Closed Night
Plot 084 - 352 - South	Bedroom2	Noise - 0.3 EA
Plot 084 - 352 - South	Bedroom3	Noise - Closed Night
Plot 084 - 352 - South	Kitchen	-
Plot 084 - 352 - South	Living	-
Plot 085 - 452 - South	Bedroom1	Noise - Closed Night
Plot 085 - 452 - South	Bedroom2	Noise - Closed Night
Plot 085 - 452 - South	Bedroom3	Noise - Closed Night
Plot 085 - 452 - South	Bedroom4	Noise - Closed Night
Plot 085 - 452 - South	Kitchen	-
Plot 085 - 452 - South	Living	-
Plot 086 - 452 - South	Bedroom1	Noise - Closed Night
Plot 086 - 452 - South	Bedroom2	Noise - Closed Night
Plot 086 - 452 - South	Bedroom3	Noise - Closed Night
Plot 086 - 452 - South	Bedroom4	Noise - Closed Night
Plot 086 - 452 - South	Kitchen	-
Plot 086 - 452 - South	Living	-
Plot 087 - 364 - West	Bedroom1	Noise - Closed Night
Plot 087 - 364 - West	Bedroom2	Noise - Closed Night
Plot 087 - 364 - West	Bedroom3	-
Plot 087 - 364 - West	Kitchen	-
Plot 087 - 364 - West	Living	-
Plot 088 - 364 - West	Bedroom1	Noise - Closed Night
Plot 088 - 364 - West	Bedroom2	Noise - Closed Night
Plot 088 - 364 - West	Bedroom3	-
Plot 088 - 364 - West	Kitchen	-
Plot 088 - 364 - West	Living	-
Plot 097 - 452 - North	Bedroom1	Noise - Closed Night
Plot 097 - 452 - North	Bedroom2	-
Plot 097 - 452 - North	Bedroom3	Noise - Closed Night
Plot 097 - 452 - North	Bedroom4	-
Plot 097 - 452 - North	Kitchen	-
Plot 097 - 452 - North	Living	-
Plot 098 - 352 - North	Bedroom1	-

Plot 098 - 352 - North	Bedroom2	Noise - Closed Night
Plot 098 - 352 - North	Bedroom3	-
Plot 098 - 352 - North	Kitchen	-
Plot 098 - 352 - North	Living	-
Plot 099 - 352 - North	Bedroom1	-
Plot 099 - 352 - North	Bedroom2	Noise - Closed Night
Plot 099 - 352 - North	Bedroom3	-
Plot 099 - 352 - North	Kitchen	-
Plot 099 - 352 - North	Living	-
Plot 100 - 236 - North	Bedroom1	Noise - Closed Night
Plot 100 - 236 - North	Bedroom2	Noise - Closed Night
Plot 100 - 236 - North	Kitchen	-
Plot 100 - 236 - North	Living	-
Plot 101 - 242 - East	Bedroom1	Noise - Restricted Openability
Plot 101 - 242 - East	Bedroom2	Noise - Restricted Openability
Plot 101 - 242 - East	Kitchen	-
Plot 101 - 242 - East	Living	-
Plot 115 - 341 - West	Bedroom1	Noise - Restricted Openability
Plot 115 - 341 - West	Bedroom2	-
Plot 115 - 341 - West	Kitchen	-
Plot 115 - 341 - West	Living	-
Plot 116 - 241 - West	Bedroom1	-
Plot 116 - 241 - West	Bedroom2	Noise - Restricted Openability
Plot 116 - 241 - West	Kitchen	-
Plot 116 - 241 - West	Living	-
Plot 117 - 341 - East	Bedroom1	Noise - Restricted Openability
Plot 117 - 341 - East	Bedroom2	-
Plot 117 - 341 - East	Kitchen	-
Plot 117 - 341 - East	Living	-
Plot 122 - 361 - West	Bedroom1	Noise - Restricted Openability
Plot 122 - 361 - West	Bedroom2	-
Plot 122 - 361 - West	Bedroom3	-
Plot 122 - 361 - West	Kitchen	-
Plot 122 - 361 - West	Living	-
Plot 123 - 361 - West	Bedroom1	Noise - Restricted Openability
Plot 123 - 361 - West	Bedroom2	-
Plot 123 - 361 - West	Bedroom3	-
Plot 123 - 361 - West	Kitchen	-
Plot 123 - 361 - West	Living	-
Plot 124 - 361 - West	Bedroom1	Noise - Restricted Openability
Plot 124 - 361 - West	Bedroom2	-
Plot 124 - 361 - West	Bedroom3	-
Plot 124 - 361 - West	Kitchen	-
Plot 124 - 361 - West	Living	-
Plot 125 - 474 - North	Bedroom1	Noise - Restricted Openability
Plot 125 - 474 - North	Bedroom2	Noise - Restricted Openability
Plot 125 - 474 - North	Bedroom3	Noise - Restricted Openability

Plot 125 - 474 - North	Bedroom4	Noise - Restricted Openability
Plot 125 - 474 - North	Kitchen	-
Plot 125 - 474 - North	Living	-
Plot 126 - 474 - North	Bedroom1	-
Plot 126 - 474 - North	Bedroom2	-
Plot 126 - 474 - North	Bedroom3	-
Plot 126 - 474 - North	Bedroom4	-
Plot 126 - 474 - North	Kitchen	-
Plot 126 - 474 - North	Living	-
Plot 134 - B01V1 - South	Bedroom1	Noise - Closed Night
Plot 134 - B01V1 - South	Bedroom2	Noise - Closed Night
Plot 134 - B01V1 - South	KitchenLiving	-
Plot 135 - B01V2 - South	Bedroom1	Noise - Closed Night
Plot 135 - B01V2 - South	Bedroom2	Noise - Closed Night
Plot 135 - B01V2 - South	KitchenLiving	-
Plot 136 - B01V1 - South	Bedroom1	Noise - Closed Night
Plot 136 - B01V1 - South	Bedroom2	Noise - Closed Night
Plot 136 - B01V1 - South	KitchenLiving	-
Plot 137 - B01V2 - South	Bedroom1	Noise - Closed Night
Plot 137 - B01V2 - South	Bedroom2	Noise - Closed Night
Plot 137 - B01V2 - South	KitchenLiving	-
Plot 138 - B01V1 - South	Bedroom1	Noise - Closed Night
Plot 138 - B01V1 - South	Bedroom2	Noise - Closed Night
Plot 138 - B01V1 - South	KitchenLiving	-
Plot 139 - B01V2 - South	Bedroom1	Noise - Closed Night
Plot 139 - B01V2 - South	Bedroom2	Noise - Closed Night
Plot 139 - B01V2 - South	KitchenLiving	-
Plot 140 - 352 - North	Bedroom1	-
Plot 140 - 352 - North	Bedroom2	-
Plot 140 - 352 - North	Bedroom3	-
Plot 140 - 352 - North	Kitchen	-
Plot 140 - 352 - North	Living	-
Plot 141 - 352 - North	Bedroom1	-
Plot 141 - 352 - North	Bedroom2	-
Plot 141 - 352 - North	Bedroom3	-
Plot 141 - 352 - North	Kitchen	-
Plot 141 - 352 - North	Living	-
Plot 142 - 352 - North	Bedroom1	-
Plot 142 - 352 - North	Bedroom2	-
Plot 142 - 352 - North	Bedroom3	-
Plot 142 - 352 - North	Kitchen	-
Plot 142 - 352 - North	Living	-
Plot 143 - 354 - North	Bedroom1	Noise - Closed Night
Plot 143 - 354 - North	Bedroom2	Noise - Restricted Openability
Plot 143 - 354 - North	Bedroom3	Noise - Restricted Openability
Plot 143 - 354 - North	Kitchen	-
Plot 143 - 354 - North	Living	-

Plot 144 - 474 - East	Bedroom1	-
Plot 144 - 474 - East	Bedroom2	Noise - Closed Night
Plot 144 - 474 - East	Bedroom3	Noise - Closed Night
Plot 144 - 474 - East	Bedroom4	-
Plot 144 - 474 - East	Kitchen	-
Plot 144 - 474 - East	Living	-
Plot 145 - 474 - East	Bedroom1	-
Plot 145 - 474 - East	Bedroom2	Noise - Closed Night
Plot 145 - 474 - East	Bedroom3	Noise - Closed Night
Plot 145 - 474 - East	Bedroom4	-
Plot 145 - 474 - East	Kitchen	-
Plot 145 - 474 - East	Living	-
Plot 146 - 474 - East	Bedroom1	-
Plot 146 - 474 - East	Bedroom2	Noise - Closed Night
Plot 146 - 474 - East	Bedroom3	Noise - Closed Night
Plot 146 - 474 - East	Bedroom4	-
Plot 146 - 474 - East	Kitchen	-
Plot 146 - 474 - East	Living	-
Plot 147 - 474 - East	Bedroom1	-
Plot 147 - 474 - East	Bedroom2	Noise - Closed Night
Plot 147 - 474 - East	Bedroom3	Noise - Closed Night
Plot 147 - 474 - East	Bedroom4	Noise - Restricted Openability
Plot 147 - 474 - East	Kitchen	-
Plot 147 - 474 - East	Living	-
Plot 148 - 474 - East	Bedroom1	Noise - Closed Night
Plot 148 - 474 - East	Bedroom2	Noise - Closed Night
Plot 148 - 474 - East	Bedroom3	Noise - Closed Night
Plot 148 - 474 - East	Bedroom4	Noise - Closed Night
Plot 148 - 474 - East	Kitchen	-
Plot 148 - 474 - East	Living	-
Plot 149 - C01V1 - North	Bedroom1	Security - Closed Night
Plot 149 - C01V1 - North	KitchenLiving	-
Plot 150 - C03V1 - North	Bedroom1	Security - Closed Night
Plot 150 - C03V1 - North	KitchenLiving	-
Plot 151 - C02 - North	Bedroom1	Security - Closed Night
Plot 151 - C02 - North	KitchenLiving	-
Plot 152 - C01V2 - North	Bedroom1	Security - Closed Night
Plot 152 - C01V2 - North	KitchenLiving	-
Plot 153 - C03V2 - North	Bedroom1	Security - Closed Night
Plot 153 - C03V2 - North	KitchenLiving	-
Plot 154 - C01V1 - North	Bedroom1	Noise - Restricted Openability
Plot 154 - C01V1 - North	KitchenLiving	-
Plot 155 - C06V1 - North	Bedroom1	-
Plot 155 - C06V1 - North	Bedroom2	-
Plot 155 - C06V1 - North	KitchenLiving	-
Plot 156 - C04 - North	Bedroom1	Noise - Restricted Openability
Plot 156 - C04 - North	Bedroom2	Noise - Restricted Openability

Plot 156 - C04 - North	KitchenLiving	-
Plot 157 - C05 - North	Bedroom1	Noise - Restricted Openability
Plot 157 - C05 - North	Bedroom2	Noise - Restricted Openability
Plot 157 - C05 - North	KitchenLiving	-
Plot 158 - C01V2 - North	Bedroom1	Noise - Closed Night
Plot 158 - C01V2 - North	KitchenLiving	-
Plot 159 - C06V2 - North	Bedroom1	Noise - Closed Night
Plot 159 - C06V2 - North	Bedroom2	Noise - Closed Night
Plot 159 - C06V2 - North	KitchenLiving	-
Plot 160 - C01V1 - North	Bedroom1	Noise - Restricted Openability
Plot 160 - C01V1 - North	KitchenLiving	-
Plot 161 - C06V1 - North	Bedroom1	-
Plot 161 - C06V1 - North	Bedroom2	-
Plot 161 - C06V1 - North	KitchenLiving	-
Plot 162 - C07 - North	Bedroom1	Noise - Restricted Openability
Plot 162 - C07 - North	Bedroom2	Noise - Restricted Openability
Plot 162 - C07 - North	KitchenLiving	-
Plot 163 - C05 - North	Bedroom1	Noise - Restricted Openability
Plot 163 - C05 - North	Bedroom2	Noise - Restricted Openability
Plot 163 - C05 - North	KitchenLiving	-
Plot 164 - C01V2 - North	Bedroom1	Noise - Closed Night
Plot 164 - C01V2 - North	KitchenLiving	-
Plot 165 - C06V2 - North	Bedroom1	Noise - Closed Night
Plot 165 - C06V2 - North	Bedroom2	Noise - Closed Night
Plot 165 - C06V2 - North	KitchenLiving	-
Plot 166 - 452 - East	Bedroom1	Noise - Closed Night
Plot 166 - 452 - East	Bedroom2	-
Plot 166 - 452 - East	Bedroom3	Noise - Closed Night
Plot 166 - 452 - East	Bedroom4	-
Plot 166 - 452 - East	Kitchen	-
Plot 166 - 452 - East	Living	-
Plot 167 - 452 - East	Bedroom1	Noise - Closed Night
Plot 167 - 452 - East	Bedroom2	-
Plot 167 - 452 - East	Bedroom3	Noise - Closed Night
Plot 167 - 452 - East	Bedroom4	-
Plot 167 - 452 - East	Kitchen	-
Plot 167 - 452 - East	Living	-
Plot 168 - 355 - South	Bedroom1	Noise - 0.15 EA
Plot 168 - 355 - South	Bedroom2	Noise - 0.15 EA
Plot 168 - 355 - South	Bedroom3	-
Plot 168 - 355 - South	Kitchen	-
Plot 168 - 355 - South	Living	-
Plot 169 - 361 - South	Bedroom1	Noise - 0.1 EA
Plot 169 - 361 - South	Bedroom2	-
Plot 169 - 361 - South	Bedroom3	-
Plot 169 - 361 - South	Kitchen	-
Plot 169 - 361 - South	Living	-

Plot 170 - 361 - South	Bedroom1	Noise - 0.1 EA
Plot 170 - 361 - South	Bedroom2	-
Plot 170 - 361 - South	Bedroom3	-
Plot 170 - 361 - South	Kitchen	-
Plot 170 - 361 - South	Living	-
Plot 173 - 361 - West	Bedroom1	Noise - 0.2 EA
Plot 173 - 361 - West	Bedroom2	-
Plot 173 - 361 - West	Bedroom3	-
Plot 173 - 361 - West	Kitchen	-
Plot 173 - 361 - West	Living	-
Plot 174 - 361 - West	Bedroom1	Noise - 0.2 EA
Plot 174 - 361 - West	Bedroom2	-
Plot 174 - 361 - West	Bedroom3	-
Plot 174 - 361 - West	Kitchen	-
Plot 174 - 361 - West	Living	-
Plot 175 - 467 - West	Bedroom1	Noise - 0.2 EA
Plot 175 - 467 - West	Bedroom2	Noise - 0.2 EA
Plot 175 - 467 - West	Bedroom3	Noise - 0.15 EA
Plot 175 - 467 - West	Bedroom4	Noise - 0.15 EA
Plot 175 - 467 - West	Dining	-
Plot 175 - 467 - West	Kitchen	-
Plot 175 - 467 - West	Living	-
Plot 182 - 591 - South	Bedroom1	Noise - 0.15 EA
Plot 182 - 591 - South	Bedroom2	Noise - 0.15 EA
Plot 182 - 591 - South	Bedroom3	Noise - 0.15 EA
Plot 182 - 591 - South	Bedroom4	Noise - 0.15 EA
Plot 182 - 591 - South	Bedroom5	-
Plot 182 - 591 - South	KitchenLiving	-
Plot 182 - 591 - South	Living	-
Plot 183 - 356 - South	Bedroom1	-
Plot 183 - 356 - South	Bedroom2	Noise - 0.15 EA
Plot 183 - 356 - South	Bedroom3	Noise - 0.15 EA
Plot 183 - 356 - South	Kitchen	-
Plot 183 - 356 - South	Living	-
Plot 184 - 356 - South	Bedroom1	-
Plot 184 - 356 - South	Bedroom2	Noise - 0.15 EA
Plot 184 - 356 - South	Bedroom3	Noise - 0.15 EA
Plot 184 - 356 - South	Kitchen	-
Plot 184 - 356 - South	Living	-
Plot 185 - 474 - South	Bedroom1	-
Plot 185 - 474 - South	Bedroom2	Noise - Restricted Openability
Plot 185 - 474 - South	Bedroom3	Noise - Restricted Openability
Plot 185 - 474 - South	Bedroom4	-
Plot 185 - 474 - South	Kitchen	-
Plot 185 - 474 - South	Living	-
Plot 186 - 474 - South	Bedroom1	-
Plot 186 - 474 - South	Bedroom2	Noise - Restricted Openability

Plot 186 - 474 - South	Bedroom3	Noise - Restricted Openability
Plot 186 - 474 - South	Bedroom4	-
Plot 186 - 474 - South	Kitchen	-
Plot 186 - 474 - South	Living	-
Plot 187 - 356 - South	Bedroom1	-
Plot 187 - 356 - South	Bedroom2	Noise - 0.15 EA
Plot 187 - 356 - South	Bedroom3	Noise - 0.15 EA
Plot 187 - 356 - South	Kitchen	-
Plot 187 - 356 - South	Living	-
Plot 188 - 356 - South	Bedroom1	-
Plot 188 - 356 - South	Bedroom2	Noise - 0.15 EA
Plot 188 - 356 - South	Bedroom3	Noise - 0.15 EA
Plot 188 - 356 - South	Kitchen	-
Plot 188 - 356 - South	Living	-
Plot 189 - 591 - South	Bedroom1	Noise - 0.15 EA
Plot 189 - 591 - South	Bedroom2	Noise - 0.15 EA
Plot 189 - 591 - South	Bedroom3	Noise - 0.15 EA
Plot 189 - 591 - South	Bedroom4	Noise - 0.15 EA
Plot 189 - 591 - South	Bedroom5	-
Plot 189 - 591 - South	KitchenLiving	-
Plot 189 - 591 - South	Living	-
Plot 196 - 356 - South	Bedroom1	-
Plot 196 - 356 - South	Bedroom2	Noise - Restricted Openability
Plot 196 - 356 - South	Bedroom3	Noise - Restricted Openability
Plot 196 - 356 - South	Kitchen	-
Plot 196 - 356 - South	Living	-
Plot 197 - 356 - South	Bedroom1	-
Plot 197 - 356 - South	Bedroom2	Noise - Restricted Openability
Plot 197 - 356 - South	Bedroom3	Noise - Restricted Openability
Plot 197 - 356 - South	Kitchen	-
Plot 197 - 356 - South	Living	-
Plot 198 - 356 - Southwest	Bedroom1	-
Plot 198 - 356 - Southwest	Bedroom2	Noise - Restricted Openability
Plot 198 - 356 - Southwest	Bedroom3	Noise - Restricted Openability
Plot 198 - 356 - Southwest	Kitchen	-
Plot 198 - 356 - Southwest	Living	-
Plot 199 - 356 - Southwest	Bedroom1	-
Plot 199 - 356 - Southwest	Bedroom2	Noise - Restricted Openability
Plot 199 - 356 - Southwest	Bedroom3	Noise - Restricted Openability
Plot 199 - 356 - Southwest	Kitchen	-
Plot 199 - 356 - Southwest	Living	-
Plot 200 - 474 - Southwest	Bedroom1	-
Plot 200 - 474 - Southwest	Bedroom2	Noise - Restricted Openability
Plot 200 - 474 - Southwest	Bedroom3	Noise - Restricted Openability
Plot 200 - 474 - Southwest	Bedroom4	-
Plot 200 - 474 - Southwest	Kitchen	-
Plot 200 - 474 - Southwest	Living	-

Plot 201 - 474 - Southwest	Bedroom1	-
Plot 201 - 474 - Southwest	Bedroom2	Noise - Restricted Openability
Plot 201 - 474 - Southwest	Bedroom3	Noise - Restricted Openability
Plot 201 - 474 - Southwest	Bedroom4	-
Plot 201 - 474 - Southwest	Kitchen	-
Plot 201 - 474 - Southwest	Living	-
Plot 202 - 474 - Southwest	Bedroom1	-
Plot 202 - 474 - Southwest	Bedroom2	Noise - Restricted Openability
Plot 202 - 474 - Southwest	Bedroom3	Noise - Restricted Openability
Plot 202 - 474 - Southwest	Bedroom4	-
Plot 202 - 474 - Southwest	Kitchen	-
Plot 202 - 474 - Southwest	Living	-
Plot 203 - 474 - Southwest	Bedroom1	-
Plot 203 - 474 - Southwest	Bedroom2	Noise - Restricted Openability
Plot 203 - 474 - Southwest	Bedroom3	Noise - Restricted Openability
Plot 203 - 474 - Southwest	Bedroom4	-
Plot 203 - 474 - Southwest	Kitchen	-
Plot 203 - 474 - Southwest	Living	-
Plot 204 - 356 - Southwest	Bedroom1	-
Plot 204 - 356 - Southwest	Bedroom2	Noise - Restricted Openability
Plot 204 - 356 - Southwest	Bedroom3	Noise - Restricted Openability
Plot 204 - 356 - Southwest	Kitchen	-
Plot 204 - 356 - Southwest	Living	-
Plot 205 - 356 - Southwest	Bedroom1	-
Plot 205 - 356 - Southwest	Bedroom2	Noise - Restricted Openability
Plot 205 - 356 - Southwest	Bedroom3	Noise - Restricted Openability
Plot 205 - 356 - Southwest	Kitchen	-
Plot 205 - 356 - Southwest	Living	-
Plot 206 - 356 - Southwest	Bedroom1	-
Plot 206 - 356 - Southwest	Bedroom2	Noise - Restricted Openability
Plot 206 - 356 - Southwest	Bedroom3	Noise - Restricted Openability
Plot 206 - 356 - Southwest	Kitchen	-
Plot 206 - 356 - Southwest	Living	-
Plot 207 - 356 - Southwest	Bedroom1	-
Plot 207 - 356 - Southwest	Bedroom2	Noise - Restricted Openability
Plot 207 - 356 - Southwest	Bedroom3	Noise - Restricted Openability
Plot 207 - 356 - Southwest	Kitchen	-
Plot 207 - 356 - Southwest	Living	-
Plot 208 - 356 - South	Bedroom1	-
Plot 208 - 356 - South	Bedroom2	Noise - Restricted Openability
Plot 208 - 356 - South	Bedroom3	Noise - Restricted Openability
Plot 208 - 356 - South	Kitchen	-
Plot 208 - 356 - South	Living	-
Plot 209 - 356 - South	Bedroom1	-
Plot 209 - 356 - South	Bedroom2	Noise - Restricted Openability
Plot 209 - 356 - South	Bedroom3	Noise - Restricted Openability
Plot 209 - 356 - South	Kitchen	-

Plot 209 - 356 - South	Living	-
Plot 210 - 474 - South	Bedroom1	-
Plot 210 - 474 - South	Bedroom2	Noise - Restricted Openability
Plot 210 - 474 - South	Bedroom3	Noise - Restricted Openability
Plot 210 - 474 - South	Bedroom4	-
Plot 210 - 474 - South	Kitchen	-
Plot 210 - 474 - South	Living	-
Plot 218 - 467 - East	Bedroom1	Noise - Restricted Openability
Plot 218 - 467 - East	Bedroom2	Noise - Restricted Openability
Plot 218 - 467 - East	Bedroom3	Noise - Restricted Openability
Plot 218 - 467 - East	Bedroom4	-
Plot 218 - 467 - East	Dining	-
Plot 218 - 467 - East	Kitchen	-
Plot 218 - 467 - East	Living	-
Plot 219 - 472 - East	Bedroom1	Noise - Restricted Openability
Plot 219 - 472 - East	Bedroom2	Noise - Restricted Openability
Plot 219 - 472 - East	Bedroom3	-
Plot 219 - 472 - East	Bedroom4	-
Plot 219 - 472 - East	KitchenLiving	-
Plot 219 - 472 - East	Living	-
Plot 220 - 352 - East	Bedroom1	-
Plot 220 - 352 - East	Bedroom2	Noise - Closed Night
Plot 220 - 352 - East	Bedroom3	-
Plot 220 - 352 - East	Kitchen	-
Plot 220 - 352 - East	Living	-
Plot 221 - 352 - East	Bedroom1	-
Plot 221 - 352 - East	Bedroom2	Noise - Closed Night
Plot 221 - 352 - East	Bedroom3	-
Plot 221 - 352 - East	Kitchen	-
Plot 221 - 352 - East	Living	-
Plot 222 - 352 - East	Bedroom1	-
Plot 222 - 352 - East	Bedroom2	Noise - Restricted Openability
Plot 222 - 352 - East	Bedroom3	-
Plot 222 - 352 - East	Kitchen	-
Plot 222 - 352 - East	Living	-
Plot 223 - 352 - East	Bedroom1	-
Plot 223 - 352 - East	Bedroom2	Noise - Restricted Openability
Plot 223 - 352 - East	Bedroom3	-
Plot 223 - 352 - East	Kitchen	-
Plot 223 - 352 - East	Living	-
Plot 224 - 352 - East	Bedroom1	-
Plot 224 - 352 - East	Bedroom2	Noise - Restricted Openability
Plot 224 - 352 - East	Bedroom3	-
Plot 224 - 352 - East	Kitchen	-
Plot 224 - 352 - East	Living	-
Plot 225 - 467 - South	Bedroom1	Noise - Restricted Openability
Plot 225 - 467 - South	Bedroom2	Noise - Restricted Openability

Plot 225 - 467 - South	Bedroom3	Noise - Restricted Openability
Plot 225 - 467 - South	Bedroom4	-
Plot 225 - 467 - South	Dining	-
Plot 225 - 467 - South	Kitchen	-
Plot 225 - 467 - South	Living	-
Plot 226 - 581 - South	Bedroom1	Noise - Restricted Openability
Plot 226 - 581 - South	Bedroom2	Noise - Restricted Openability
Plot 226 - 581 - South	Bedroom3	-
Plot 226 - 581 - South	Bedroom4	-
Plot 226 - 581 - South	Bedroom5	-
Plot 226 - 581 - South	KitchenLiving	-
Plot 226 - 581 - South	Living	-
Plot 227 - 467 - South	Bedroom1	Noise - Restricted Openability
Plot 227 - 467 - South	Bedroom2	Noise - Restricted Openability
Plot 227 - 467 - South	Bedroom3	-
Plot 227 - 467 - South	Bedroom4	-
Plot 227 - 467 - South	Dining	-
Plot 227 - 467 - South	Kitchen	-
Plot 227 - 467 - South	Living	-
Plot 233 - 571 - North	Bedroom1	Noise - Restricted Openability
Plot 233 - 571 - North	Bedroom2	Noise - Restricted Openability
Plot 233 - 571 - North	Bedroom3	Noise - Restricted Openability
Plot 233 - 571 - North	Bedroom4	Noise - Closed Night
Plot 233 - 571 - North	Bedroom5	Noise - Closed Night
Plot 233 - 571 - North	KitchenLiving	-
Plot 233 - 571 - North	Living	-
Plot 237 - 341 - South	Bedroom1	Noise - Restricted Openability
Plot 237 - 341 - South	Bedroom2	-
Plot 237 - 341 - South	Kitchen	-
Plot 237 - 341 - South	Living	-
Plot 238 - 354 - West	Bedroom1	Noise - Closed Night
Plot 238 - 354 - West	Bedroom2	Noise - Closed Night
Plot 238 - 354 - West	Bedroom3	Noise - Restricted Openability
Plot 238 - 354 - West	Kitchen	-
Plot 238 - 354 - West	Living	-
Plot 239 - 467 - North	Bedroom1	-
Plot 239 - 467 - North	Bedroom2	Noise - Restricted Openability
Plot 239 - 467 - North	Bedroom3	Noise - Closed Night
Plot 239 - 467 - North	Bedroom4	Noise - Restricted Openability
Plot 239 - 467 - North	Dining	-
Plot 239 - 467 - North	Kitchen	-
Plot 239 - 467 - North	Living	-
Plot 251 - 467 - North	Bedroom1	Noise - Restricted Openability
Plot 251 - 467 - North	Bedroom2	Noise - Closed Night
Plot 251 - 467 - North	Bedroom3	Noise - Closed Night
Plot 251 - 467 - North	Bedroom4	Noise - Restricted Openability
Plot 251 - 467 - North	Dining	-

Plot 251 - 467 - North	Kitchen	-
Plot 251 - 467 - North	Living	-
Plot 252 - 361 - East	Bedroom1	Noise - Closed Night
Plot 252 - 361 - East	Bedroom2	-
Plot 252 - 361 - East	Bedroom3	-
Plot 252 - 361 - East	Kitchen	-
Plot 252 - 361 - East	Living	-
Plot 253 - 467 - East	Bedroom1	Noise - Restricted Openability
Plot 253 - 467 - East	Bedroom2	Noise - Restricted Openability
Plot 253 - 467 - East	Bedroom3	Noise - Restricted Openability
Plot 253 - 467 - East	Bedroom4	-
Plot 253 - 467 - East	Dining	-
Plot 253 - 467 - East	Kitchen	-
Plot 253 - 467 - East	Living	-
Plot 254 - 467 - Southwest	Bedroom1	Noise - Closed Night
Plot 254 - 467 - Southwest	Bedroom2	Noise - Restricted Openability
Plot 254 - 467 - Southwest	Bedroom3	Noise - Restricted Openability
Plot 254 - 467 - Southwest	Bedroom4	-
Plot 254 - 467 - Southwest	Dining	-
Plot 254 - 467 - Southwest	Kitchen	-
Plot 254 - 467 - Southwest	Living	-
Plot 255 - 364 - West	Bedroom1	Noise - Restricted Openability
Plot 255 - 364 - West	Bedroom2	Noise - Restricted Openability
Plot 255 - 364 - West	Bedroom3	-
Plot 255 - 364 - West	Kitchen	-
Plot 255 - 364 - West	Living	-
Plot 256 - 364 - West	Bedroom1	Noise - Restricted Openability
Plot 256 - 364 - West	Bedroom2	Noise - Restricted Openability
Plot 256 - 364 - West	Bedroom3	-
Plot 256 - 364 - West	Kitchen	-
Plot 256 - 364 - West	Living	-
Plot 257 - 364 - West	Bedroom1	Noise - Restricted Openability
Plot 257 - 364 - West	Bedroom2	Noise - Restricted Openability
Plot 257 - 364 - West	Bedroom3	-
Plot 257 - 364 - West	Kitchen	-
Plot 257 - 364 - West	Living	-
Plot 258 - 467 - North	Bedroom1	Noise - Closed Night
Plot 258 - 467 - North	Bedroom2	Noise - Closed Night
Plot 258 - 467 - North	Bedroom3	Noise - Restricted Openability
Plot 258 - 467 - North	Bedroom4	Noise - Restricted Openability
Plot 258 - 467 - North	Dining	-
Plot 258 - 467 - North	Kitchen	-
Plot 258 - 467 - North	Living	-
Plot 259 - 361 - North	Bedroom1	Noise - Closed Night
Plot 259 - 361 - North	Bedroom2	-
Plot 259 - 361 - North	Bedroom3	-
Plot 259 - 361 - North	Kitchen	-

Plot 259 - 361 - North	Living	-
Plot 260 - 361 - North	Bedroom1	Noise - Closed Night
Plot 260 - 361 - North	Bedroom2	-
Plot 260 - 361 - North	Bedroom3	-
Plot 260 - 361 - North	Kitchen	-
Plot 260 - 361 - North	Living	-
Plot 261 - Kirdford - Northeast	Bedroom1	Noise - Restricted Openability
Plot 261 - Kirdford - Northeast	Bedroom2	Security - Closed Night
Plot 261 - Kirdford - Northeast	Bedroom3	Security - Closed Night
Plot 261 - Kirdford - Northeast	KitchenLiving	-
Plot 262 - Kirdford - East	Bedroom1	Noise - Restricted Openability
Plot 262 - Kirdford - East	Bedroom2	Security - Closed Night
Plot 262 - Kirdford - East	Bedroom3	Security - Closed Night
Plot 262 - Kirdford - East	KitchenLiving	-
Plot 263 - Kirdford - East	Bedroom1	Noise - Restricted Openability
Plot 263 - Kirdford - East	Bedroom2	Security - Closed Night
Plot 263 - Kirdford - East	Bedroom3	Security - Closed Night
Plot 263 - Kirdford - East	KitchenLiving	-
Plot 264 - Kirdford - East	Bedroom1	Noise - Restricted Openability
Plot 264 - Kirdford - East	Bedroom2	Security - Closed Night
Plot 264 - Kirdford - East	Bedroom3	Security - Closed Night
Plot 264 - Kirdford - East	KitchenLiving	-
Plot 265 - Kirdford - East	Bedroom1	Noise - Restricted Openability
Plot 265 - Kirdford - East	Bedroom2	Security - Closed Night
Plot 265 - Kirdford - East	Bedroom3	Security - Closed Night
Plot 265 - Kirdford - East	KitchenLiving	-

Fan l/s	Changes	A	B	Result
-		0.62	16.17	Pass
70 l/s Extract Fan		0.3	29.5	Pass
10 l/s Extract Fan		1.17	28	Pass
-		1.04	N/A	Pass
-		1.32	N/A	Pass
-		0.59	16.83	Pass
70 l/s Extract Fan		0.27	25.67	Pass
-		1.07	28.5	Pass
-		0.98	N/A	Pass
-		1.12	N/A	Pass
-		0.61	17.33	Pass
70 l/s Extract Fan		0.28	28	Pass
20 l/s Extract Fan		1.03	26.83	Pass
-		1	N/A	Pass
-		1.16	N/A	Pass
-		0.61	17.33	Pass
70 l/s Extract Fan		0.28	27.5	Pass
10 l/s Extract Fan		1.1	27	Pass
-		1.02	N/A	Pass
-		1.21	N/A	Pass
10 l/s Extract Fan		1.44	31.83	Pass
10 l/s Extract Fan		0.75	29.33	Pass
-		0.98	N/A	Pass
-		1.78	N/A	Pass
10 l/s Extract Fan		1.35	30.17	Pass
10 l/s Extract Fan		0.75	31.17	Pass
-		0.96	N/A	Pass
-		1.74	N/A	Pass
40 l/s Extract Fan		0.6	28.67	Pass
80 l/s Extract Fan - Window made triple opening casement		0.2	29.33	Pass
50 l/s Extract Fan		0.58	28.83	Pass
30 l/s Extract Fan		0.66	28.17	Pass
-		1.06	N/A	Pass
-		0.8	N/A	Pass
50 l/s Extract Fan		0.54	30.17	Pass
80 l/s Extract Fan - Window made triple opening casement		0.31	31.33	Pass
50 l/s Extract Fan		0.62	28.67	Pass
40 l/s Extract Fan		0.72	28	Pass
-		0.82	N/A	Pass
-		1.04	N/A	Pass
15 l/s Extract Fan		0.54	29.83	Pass
70 l/s Extract Fan - Window made triple opening casement		0.29	30.83	Pass
-		0.63	23.67	Pass
-		0.73	26.33	Pass
-		0.84	N/A	Pass
-		1.02	N/A	Pass

35 l/s Extract Fan	0.52	30.33	Pass
70 l/s Extract Fan	0.17	29.83	Pass
30 l/s Extract Fan	0.58	31.33	Pass
-	1.18	N/A	Pass
-	0.53	N/A	Pass
-	0.43	20.33	Pass
70 l/s Extract Fan	0.16	29	Pass
30 l/s Extract Fan	0.53	28.83	Pass
-	1.01	N/A	Pass
-	0.4	N/A	Pass
-	0.43	20.33	Pass
70 l/s Extract Fan	0.17	25	Pass
25 l/s Extract Fan	0.53	24.83	Pass
-	1.06	N/A	Pass
-	0.42	N/A	Pass
-	0.44	20.83	Pass
70 l/s Extract Fan	0.17	26.67	Pass
25 l/s Extract Fan	0.56	25.5	Pass
-	1.06	N/A	Pass
-	0.46	N/A	Pass
-	0.58	22	Pass
70 l/s Extract Fan - Window made triple opening casement	0.21	29.67	Pass
20 l/s Extract Fan	0.57	29.17	Pass
-	1.03	23.33	Pass
-	1.2	N/A	Pass
-	0.84	N/A	Pass
-	0.58	22	Pass
70 l/s Extract Fan - Window made triple opening casement	0.21	29.5	Pass
20 l/s Extract Fan	0.57	28.67	Pass
-	1.01	23.33	Pass
-	1.21	N/A	Pass
-	0.82	N/A	Pass
-	0.58	22	Pass
70 l/s Extract Fan - Window made triple opening casement	0.2	28.33	Pass
20 l/s Extract Fan	0.56	28.67	Pass
-	0.68	22.33	Pass
-	1.06	N/A	Pass
-	0.78	N/A	Pass
-	0.48	15.5	Pass
-	0.22	27	Pass
-	0.56	18.5	Pass
-	0.53	16.67	Pass
-	0.55	N/A	Pass
-	0.98	N/A	Pass
-	0.48	15.83	Pass
-	0.23	28.33	Pass
-	0.56	18.33	Pass

-	0.71	17.83	Pass
-	0.74	N/A	Pass
-	0.98	N/A	Pass
-	0.48	16	Pass
-	0.23	28.17	Pass
-	0.56	18.33	Pass
-	0.71	17.83	Pass
-	0.78	N/A	Pass
-	0.97	N/A	Pass
-	0.4	16.5	Pass
-	0.19	23	Pass
-	0.64	19.67	Pass
-	0.51	N/A	Pass
-	0.73	N/A	Pass
-	0.43	15.67	Pass
-	0.19	23.33	Pass
-	0.62	21	Pass
-	0.54	N/A	Pass
-	0.73	N/A	Pass
-	0.5	16.67	Pass
Window made triple opening casement	0.21	23.5	Pass
-	0.62	22.83	Pass
-	0.74	22	Pass
-	0.76	N/A	Pass
-	1.05	N/A	Pass
40 l/s Extract Fan	0.54	28.5	Pass
80 l/s Extract Fan - Window made triple opening casement	0.25	29.17	Pass
50 l/s Extract Fan	0.63	28.67	Pass
20 l/s Extract Fan	0.75	26.67	Pass
-	0.83	N/A	Pass
-	1.01	N/A	Pass
40 l/s Extract Fan	0.36	27.5	Pass
-	0.49	N/A	Pass
50 l/s Extract Fan	0.52	28	Pass
-	0.81	N/A	Pass
25 l/s Extract Fan	0.17	29	Pass
25 l/s Extract Fan	0.24	29.17	Pass
-	0.51	N/A	Pass
30 l/s Extract Fan	0.56	28.5	Pass
-	1.38	N/A	Pass
15 l/s Extract Fan	0.3	23.67	Pass
15 l/s Extract Fan	0.34	23.5	Pass
-	0.69	N/A	Pass
30 l/s Extract Fan	0.63	25.83	Pass
30 l/s Extract Fan	0.66	25.83	Pass
-	1.47	N/A	Pass
25 l/s Extract Fan	0.34	31.67	Pass

-	0.13	N/A	Pass
-	0.26	11.83	Pass
-	0.38	13.83	Pass
-	0.49	N/A	Pass
30 l/s Extract Fan	0.48	30	Pass
-	0.66	N/A	Pass
35 l/s Extract Fan	0.45	31.83	Pass
-	0.47	N/A	Pass
20 l/s Extract Fan	0.14	30.67	Pass
20 l/s Extract Fan	0.14	30	Pass
-	0.36	N/A	Pass
-	0.5	11	Pass
-	1	N/A	Pass
-	0.49	11.33	Pass
-	0.5	11.5	Pass
-	0.98	N/A	Pass
-	0.23	14	Pass
-	0.25	14	Pass
-	0.52	N/A	Pass
20 l/s Extract Fan	0.23	27.5	Pass
-	0.52	N/A	Pass
-	0.44	8.67	Pass
-	0.37	10.83	Pass
-	0.8	N/A	Pass
20 l/s Extract Fan	0.64	31.17	Pass
-	0.61	29.83	Pass
-	0.67	N/A	Pass
-	1.01	N/A	Pass
-	0.48	18	Pass
30 l/s Extract Fan	0.46	29.83	Pass
-	0.52	N/A	Pass
-	0.8	N/A	Pass
-	0.46	19	Pass
40 l/s Extract Fan	0.46	28.67	Pass
-	0.54	21.17	Pass
-	0.39	N/A	Pass
-	0.8	N/A	Pass
-	0.46	19.5	Pass
40 l/s Extract Fan	0.45	28.33	Pass
-	0.54	21.17	Pass
-	0.4	N/A	Pass
-	0.8	N/A	Pass
-	0.5	20.17	Pass
30 l/s Extract Fan	0.51	29.67	Pass
-	0.51	N/A	Pass
-	0.83	N/A	Pass
-	0.5	18.17	Pass

30 l/s Extract Fan	0.53	31.33	Pass
-	0.51	N/A	Pass
-	0.82	N/A	Pass
-	0.47	19.67	Pass
30 l/s Extract Fan	0.46	28.67	Pass
-	0.51	N/A	Pass
-	0.82	N/A	Pass
40 l/s Extract Fan	0.68	30.83	Pass
40 l/s Extract Fan	0.79	29.67	Pass
-	0.88	N/A	Pass
-	1.08	N/A	Pass
-	0.57	15.5	Pass
40 l/s Extract Fan	0.87	31.17	Pass
-	0.66	18.17	Pass
-	0.89	N/A	Pass
-	0.89	N/A	Pass
-	0.57	14.83	Pass
40 l/s Extract Fan	0.85	29.33	Pass
-	0.65	18	Pass
-	0.89	N/A	Pass
-	0.97	N/A	Pass
-	0.78	24.5	Pass
15 l/s Extract Fan	0.58	29	Pass
-	1.86	N/A	Pass
-	0.98	N/A	Pass
-	0.71	24.83	Pass
30 l/s Extract Fan	0.58	29.83	Pass
-	1.7	N/A	Pass
-	0.91	N/A	Pass
-	0.72	22.5	Pass
45 l/s Extract Fan	0.56	31.17	Pass
-	1.72	N/A	Pass
-	0.92	N/A	Pass
-	0.72	22.67	Pass
40 l/s Extract Fan	0.55	31	Pass
-	1.67	N/A	Pass
-	0.91	N/A	Pass
-	0.67	23.33	Pass
-	1.11	26.17	Pass
-	1.76	N/A	Pass
-	1.04	N/A	Pass
-	0.68	22.67	Pass
-	1.11	25	Pass
-	1.52	N/A	Pass
-	1	N/A	Pass
30 l/s Extract Fan	0.68	26.83	Pass
40 l/s Extract Fan	1.09	28.67	Pass

15 l/s Extract Fan	0.86	30.17	Pass
-	1.37	N/A	Pass
-	0.83	N/A	Pass
-	0.41	24.67	Pass
40 l/s Extract Fan	0.42	31.83	Pass
-	0.81	N/A	Pass
-	0.57	N/A	Pass
20 l/s Extract Fan	0.61	29.67	Pass
-	0.49	26.83	Pass
-	0.81	N/A	Pass
-	0.64	N/A	Pass
20 l/s Extract Fan	0.62	30.33	Pass
-	0.49	27	Pass
-	0.83	N/A	Pass
-	0.67	N/A	Pass
20 l/s Extract Fan	0.65	31.33	Pass
-	0.6	29	Pass
-	0.83	N/A	Pass
-	0.67	N/A	Pass
20 l/s Extract Fan	1.08	28.67	Pass
50 l/s Extract Fan	1.06	31.83	Pass
15 l/s Extract Fan	0.74	31.33	Pass
-	1.34	N/A	Pass
-	1.15	N/A	Pass
-	0.44	17.67	Pass
-	0.44	17.33	Pass
-	0.5	19	Pass
-	0.45	N/A	Pass
-	0.79	N/A	Pass
-	0.63	18.33	Pass
-	0.72	16.83	Pass
-	0.52	19.5	Pass
-	0.6	N/A	Pass
-	1.03	N/A	Pass
-	0.63	18.33	Pass
-	0.71	16.83	Pass
-	0.52	19.5	Pass
-	0.6	N/A	Pass
-	1.02	N/A	Pass
-	0.45	17.83	Pass
-	0.44	17.33	Pass
-	0.49	19	Pass
-	0.44	N/A	Pass
-	0.79	N/A	Pass
30 l/s Extract Fan	1.08	28.33	Pass
60 l/s Extract Fan	1.13	31.83	Pass
40 l/s Extract Fan	0.69	30.17	Pass

-	1.7	N/A	Pass
-	1.2	N/A	Pass
30 l/s Extract Fan	0.66	31.67	Pass
50 l/s Extract Fan	0.62	31.17	Pass
-	0.86	N/A	Pass
-	0.69	N/A	Pass
60 l/s Extract Fan	0.59	32	Pass
40 l/s Extract Fan	1.01	30	Pass
50 l/s Extract Fan	0.65	31.83	Pass
-	2.07	N/A	Pass
-	0.8	N/A	Pass
60 l/s Extract Fan	0.59	31.33	Pass
40 l/s Extract Fan	1.02	30	Pass
40 l/s Extract Fan	0.7	31.17	Pass
-	2.07	N/A	Pass
-	0.78	N/A	Pass
-	0.64	13.5	Pass
-	1.09	13.33	Pass
-	0.86	27.5	Pass
-	1.29	N/A	Pass
-	0.73	N/A	Pass
40 l/s Extract Fan	0.99	30	Pass
-	0.62	15.5	Pass
-	2.03	N/A	Pass
-	0.95	N/A	Pass
50 l/s Extract Fan	0.96	31.83	Pass
-	0.62	23	Pass
-	1.99	N/A	Pass
-	0.93	N/A	Pass
40 l/s Extract Fan	1	31	Pass
-	0.62	21.33	Pass
-	1.88	N/A	Pass
-	0.91	N/A	Pass
20 l/s Extract Fan	1.06	31.33	Pass
-	0.63	14.67	Pass
-	2	N/A	Pass
-	0.99	N/A	Pass
20 l/s Extract Fan	0.55	28	Pass
-	0.45	18	Pass
-	0.54	N/A	Pass
-	0.77	N/A	Pass
30 l/s Extract Fan	0.41	24.83	Pass
30 l/s Extract Fan	0.48	28.5	Pass
-	0.47	N/A	Pass
-	0.79	N/A	Pass
50 l/s Extract Fan	0.42	28.83	Pass
30 l/s Extract Fan	0.45	31	Pass

40 l/s Extract Fan	0.55	29.17	Pass
-	0.35	N/A	Pass
-	0.78	N/A	Pass
50 l/s Extract Fan	0.45	30	Pass
30 l/s Extract Fan	0.47	32	Pass
40 l/s Extract Fan	0.57	29.33	Pass
-	0.36	N/A	Pass
-	0.79	N/A	Pass
50 l/s Extract Fan	0.47	29.67	Pass
30 l/s Extract Fan	0.46	28.83	Pass
40 l/s Extract Fan	0.57	29.17	Pass
-	0.37	N/A	Pass
-	0.79	N/A	Pass
50 l/s Extract Fan	0.5	31.17	Pass
30 l/s Extract Fan	0.47	29.67	Pass
40 l/s Extract Fan	0.58	29.67	Pass
-	0.41	N/A	Pass
-	0.82	N/A	Pass
65 l/s Extract Fan	0.5	31.43	Pass
60 l/s Extract Fan	0.63	31.17	Pass
60 l/s Extract Fan	0.58	29.67	Pass
50 l/s Extract Fan	0.61	30	Pass
-	0.77	N/A	Pass
-	0.85	N/A	Pass
65 l/s Extract Fan	0.5	31.53	Pass
60 l/s Extract Fan	0.62	31.17	Pass
60 l/s Extract Fan	0.58	29.67	Pass
50 l/s Extract Fan	0.61	30.33	Pass
-	0.77	N/A	Pass
-	0.85	N/A	Pass
-	1.19	27.17	Pass
60 l/s Extract Fan	1.25	31.5	Pass
-	0.81	23.67	Pass
-	1.23	N/A	Pass
-	2.2	N/A	Pass
-	1.14	26.83	Pass
60 l/s Extract Fan	1.2	29	Pass
-	0.77	21.5	Pass
-	1.17	N/A	Pass
-	2.1	N/A	Pass
60 l/s Extract Fan	0.57	30	Pass
10 l/s Extract Fan	0.61	29.83	Pass
50 l/s Extract Fan	0.63	30	Pass
-	0.64	27.67	Pass
-	1.05	N/A	Pass
-	0.57	N/A	Pass
-	0.52	21	Pass

35 l/s Extract Fan	0.53	31.67	Pass
-	0.74	23.33	Pass
-	1.18	N/A	Pass
-	0.46	N/A	Pass
-	0.52	21.17	Pass
35 l/s Extract Fan	0.53	31.33	Pass
-	0.74	23.17	Pass
-	1.18	N/A	Pass
-	0.46	N/A	Pass
40 l/s Extract Fan	0.61	28.67	Pass
40 l/s Extract Fan	0.41	27.5	Pass
-	1.16	N/A	Pass
-	0.91	N/A	Pass
35 l/s Extract Fan	0.9	30	Pass
30 l/s Extract Fan	0.64	29.83	Pass
-	1.49	N/A	Pass
-	1	N/A	Pass
-	1.23	28.33	Pass
-	0.71	19.17	Pass
-	0.96	N/A	Pass
-	1.65	N/A	Pass
-	0.61	19.5	Pass
30 l/s Extract Fan	0.75	31.17	Pass
-	0.94	N/A	Pass
-	1.25	N/A	Pass
-	1.29	28.67	Pass
-	0.67	17	Pass
-	0.98	N/A	Pass
-	1.49	N/A	Pass
35 l/s Extract Fan	0.97	31.17	Pass
-	0.79	16.5	Pass
-	0.8	16.67	Pass
-	1.75	N/A	Pass
-	1.8	N/A	Pass
35 l/s Extract Fan	1.27	30.83	Pass
-	0.8	16.5	Pass
-	0.96	17	Pass
-	1.97	N/A	Pass
-	2.28	N/A	Pass
30 l/s Extract Fan	1.03	31.5	Pass
-	1.04	16.83	Pass
-	0.85	16.83	Pass
-	1.74	N/A	Pass
-	1.8	N/A	Pass
40 l/s Extract Fan	0.62	30.33	Pass
70 l/s Extract Fan - Window made triple opening casement	0.21	29.67	Pass
30 l/s Extract Fan	0.58	31.5	Pass

30 l/s Extract Fan	1.01	29.33	Pass
-	1.17	N/A	Pass
-	0.83	N/A	Pass
-	0.58	17.5	Pass
Window made triple opening casement	0.17	18.67	Pass
-	0.51	15.5	Pass
-	0.94	18.83	Pass
-	1.28	N/A	Pass
-	0.8	N/A	Pass
35 l/s Extract Fan	0.36	30	Pass
35 l/s Extract Fan	0.37	30.83	Pass
-	1.3	N/A	Pass
30 l/s Extract Fan	0.24	31.67	Pass
30 l/s Extract Fan	0.29	31.23	Pass
-	0.99	N/A	Pass
30 l/s Extract Fan	0.31	27	Pass
30 l/s Extract Fan	0.32	26.83	Pass
-	1.15	N/A	Pass
30 l/s Extract Fan	0.19	25.33	Pass
30 l/s Extract Fan	0.21	26.17	Pass
-	0.94	N/A	Pass
30 l/s Extract Fan	0.46	26.83	Pass
30 l/s Extract Fan	0.5	27.33	Pass
-	1.99	N/A	Pass
30 l/s Extract Fan	0.52	25.83	Pass
30 l/s Extract Fan	0.55	26.17	Pass
-	1.7	N/A	Pass
-	0.5	15.83	Pass
-	0.46	14.67	Pass
-	0.72	18.83	Pass
-	1.12	N/A	Pass
-	0.44	N/A	Pass
-	0.49	15.5	Pass
-	0.44	14.17	Pass
-	0.71	18.5	Pass
-	1.5	N/A	Pass
-	0.67	N/A	Pass
-	0.51	16.5	Pass
-	0.47	14.83	Pass
-	0.72	19.17	Pass
-	1.53	N/A	Pass
-	0.48	N/A	Pass
30 l/s Extract Fan	0.65	23.67	Pass
30 l/s Extract Fan	0.54	30.67	Pass
40 l/s Extract Fan	0.95	31	Pass
-	1.54	N/A	Pass
-	0.86	N/A	Pass

-	0.93	22	Pass
90 l/s Extract Fan - Window made triple opening casement	0.21	28.67	Pass
40 l/s Extract Fan	0.69	30	Pass
-	1.1	22.83	Pass
-	1.75	N/A	Pass
-	1.19	N/A	Pass
-	0.93	22.33	Pass
80 l/s Extract Fan - Window made triple opening casement	0.22	31.5	Pass
40 l/s Extract Fan	0.7	28.17	Pass
-	1.43	25.67	Pass
-	2.24	N/A	Pass
-	1.22	N/A	Pass
-	0.95	23.17	Pass
90 l/s Extract Fan - Window made triple opening casement	0.22	29.17	Pass
50 l/s Extract Fan	0.72	26.83	Pass
-	1.44	25.33	Pass
-	2.35	N/A	Pass
-	1.28	N/A	Pass
-	0.95	23	Pass
90 l/s Extract Fan - Window made triple opening casement	0.21	28	Pass
50 l/s Extract Fan	0.7	26.5	Pass
20 l/s Extract Fan	1.42	29.33	Pass
-	2.29	N/A	Pass
-	1.27	N/A	Pass
60 l/s Extract Fan	0.94	29.83	Pass
90 l/s Extract Fan - Window made triple opening casement	0.22	30.5	Pass
60 l/s Extract Fan	0.73	28.33	Pass
40 l/s Extract Fan	1.41	30.83	Pass
-	2.29	N/A	Pass
-	1.31	N/A	Pass
40 l/s Extract Fan	0.42	29.33	Pass
-	0.5	N/A	Pass
50 l/s Extract Fan	0.53	28.17	Pass
-	0.96	N/A	Pass
30 l/s Extract Fan	0.09	29	Pass
-	0.19	N/A	Pass
50 l/s Extract Fan	0.39	31.17	Pass
-	0.73	N/A	Pass
55 l/s Extract Fan	0.51	31	Pass
-	0.79	N/A	Pass
30 l/s Extract Fan	0.26	29	Pass
-	0.4	N/A	Pass
-	0.37	14.33	Pass
-	0.38	14.5	Pass
-	1.01	N/A	Pass
20 l/s Extract Fan	0.39	26.67	Pass
20 l/s Extract Fan	0.3	26	Pass

-	0.43	N/A	Pass
20 l/s Extract Fan	0.39	25.83	Pass
20 l/s Extract Fan	0.3	26	Pass
-	0.19	N/A	Pass
50 l/s Extract Fan	0.37	31.67	Pass
-	0.64	N/A	Pass
55 l/s Extract Fan	0.48	30.5	Pass
50 l/s Extract Fan	0.49	31.5	Pass
-	0.79	N/A	Pass
40 l/s Extract Fan	0.68	26.17	Pass
-	0.78	N/A	Pass
-	0.72	21	Pass
-	0.74	21.17	Pass
-	1.68	N/A	Pass
20 l/s Extract Fan	0.43	32	Pass
20 l/s Extract Fan	0.48	31.67	Pass
-	0.89	N/A	Pass
30 l/s Extract Fan	0.43	25.67	Pass
20 l/s Extract Fan	0.4	28.33	Pass
-	0.46	N/A	Pass
55 l/s Extract Fan	0.58	29.67	Pass
-	1	N/A	Pass
50 l/s Extract Fan	0.75	30.83	Pass
50 l/s Extract Fan	0.78	30.83	Pass
-	1.38	N/A	Pass
60 l/s Extract Fan	0.7	31.33	Pass
10 l/s Extract Fan	0.86	30.83	Pass
55 l/s Extract Fan	0.76	30.67	Pass
-	0.93	28.33	Pass
-	1.74	N/A	Pass
-	1.2	N/A	Pass
60 l/s Extract Fan	0.73	32	Pass
30 l/s Extract Fan	0.85	26.83	Pass
55 l/s Extract Fan	0.75	30.17	Pass
-	0.93	28.17	Pass
-	1.76	N/A	Pass
-	1.21	N/A	Pass
-	1.04	27.17	Pass
10 l/s Extract Fan	0.6	27.83	Pass
-	0.56	13.5	Pass
-	0.54	N/A	Pass
-	1.6	N/A	Pass
30 l/s Extract Fan	0.52	31	Pass
-	0.59	18	Pass
-	0.61	18.33	Pass
-	0.97	N/A	Pass
-	0.84	N/A	Pass

35 l/s Extract Fan	0.54	31.67	Pass
-	0.6	18.5	Pass
-	0.63	19.17	Pass
-	1.02	N/A	Pass
-	0.84	N/A	Pass
20 l/s Extract Fan	1.09	30.5	Pass
-	0.96	16	Pass
-	0.75	16	Pass
-	1.43	N/A	Pass
-	1.81	N/A	Pass
20 l/s Extract Fan	1.12	31.67	Pass
-	0.97	16.17	Pass
-	0.78	16.67	Pass
-	1.46	N/A	Pass
-	1.94	N/A	Pass
-	0.97	16.83	Pass
40 l/s Extract Fan	1.75	29.5	Pass
30 l/s Extract Fan	0.74	30.5	Pass
30 l/s Extract Fan	0.77	24.5	Pass
All casements made openable	2.92	N/A	Pass
-	0.93	N/A	Pass
-	1.96	N/A	Pass
20 l/s Extract Fan	0.67	29.5	Pass
20 l/s Extract Fan	0.69	28.17	Pass
20 l/s Extract Fan	0.66	28.5	Pass
50 l/s Extract Fan	0.78	29.83	Pass
-	0.6	23	Pass
-	1.37	N/A	Pass
-	1.57	N/A	Pass
-	0.43	16.67	Pass
70 l/s Extract Fan	0.21	28.17	Pass
25 l/s Extract Fan	0.64	29.5	Pass
-	0.51	N/A	Pass
-	0.73	N/A	Pass
-	0.44	16.83	Pass
70 l/s Extract Fan	0.21	28	Pass
25 l/s Extract Fan	0.64	29.5	Pass
-	0.54	N/A	Pass
-	0.73	N/A	Pass
-	0.52	18.17	Pass
70 l/s Extract Fan - Window made triple opening casement	0.22	30.33	Pass
30 l/s Extract Fan	0.64	30	Pass
-	0.76	19.83	Pass
-	0.84	N/A	Pass
-	1.03	N/A	Pass
-	0.52	17.83	Pass
70 l/s Extract Fan - Window made triple opening casement	0.22	29.67	Pass

30 l/s Extract Fan	0.62	30	Pass
-	0.76	19.83	Pass
-	0.82	N/A	Pass
-	1	N/A	Pass
-	0.42	16.67	Pass
70 l/s Extract Fan	0.2	28.17	Pass
25 l/s Extract Fan	0.64	29.5	Pass
-	0.51	N/A	Pass
-	0.73	N/A	Pass
-	0.43	16.83	Pass
70 l/s Extract Fan	0.21	27.67	Pass
25 l/s Extract Fan	0.62	29.33	Pass
-	0.53	N/A	Pass
-	0.73	N/A	Pass
20 l/s Extract Fan	0.78	31.33	Pass
20 l/s Extract Fan	0.69	28.33	Pass
20 l/s Extract Fan	0.65	28.83	Pass
50 l/s Extract Fan	0.75	29.5	Pass
-	0.6	22	Pass
-	1.18	N/A	Pass
-	1.48	N/A	Pass
-	0.4	15.5	Pass
70 l/s Extract Fan	0.23	27.67	Pass
10 l/s Extract Fan	0.84	28.83	Pass
-	0.53	N/A	Pass
-	0.8	N/A	Pass
-	0.39	14.67	Pass
70 l/s Extract Fan	0.2	27	Pass
25 l/s Extract Fan	0.79	27.33	Pass
-	0.49	N/A	Pass
-	0.73	N/A	Pass
-	0.4	14.83	Pass
60 l/s Extract Fan	0.28	30.5	Pass
20 l/s Extract Fan	0.93	26.5	Pass
-	0.62	N/A	Pass
-	0.8	N/A	Pass
-	0.4	14.67	Pass
60 l/s Extract Fan	0.27	29.5	Pass
20 l/s Extract Fan	0.89	25.83	Pass
-	0.59	N/A	Pass
-	0.75	N/A	Pass
-	0.51	15.33	Pass
70 l/s Extract Fan - Window made triple opening casement	0.41	31.17	Pass
30 l/s Extract Fan	0.92	27.33	Pass
-	0.77	17.5	Pass
-	0.89	N/A	Pass
-	1.71	N/A	Pass

-	0.49	14.83	Pass
70 l/s Extract Fan - Window made triple opening casement	0.37	29.5	Pass
30 l/s Extract Fan	0.89	26.33	Pass
-	0.76	17.17	Pass
-	0.84	N/A	Pass
-	1.63	N/A	Pass
-	0.49	15.17	Pass
70 l/s Extract Fan - Window made triple opening casement	0.4	30.67	Pass
30 l/s Extract Fan	0.9	26.83	Pass
-	0.77	17.5	Pass
-	0.87	N/A	Pass
-	1.64	N/A	Pass
-	0.49	15	Pass
70 l/s Extract Fan - Window made triple opening casement	0.38	29.67	Pass
30 l/s Extract Fan	0.89	26.33	Pass
-	0.77	17.17	Pass
-	0.87	N/A	Pass
-	1.64	N/A	Pass
-	0.4	14.83	Pass
60 l/s Extract Fan	0.28	30.33	Pass
20 l/s Extract Fan	0.93	27	Pass
-	0.62	N/A	Pass
-	0.84	N/A	Pass
-	0.39	14.5	Pass
60 l/s Extract Fan	0.24	28.33	Pass
20 l/s Extract Fan	0.85	24.67	Pass
-	0.56	N/A	Pass
-	0.7	N/A	Pass
-	0.39	14.83	Pass
60 l/s Extract Fan	0.27	30.5	Pass
20 l/s Extract Fan	0.85	26.67	Pass
-	0.57	N/A	Pass
-	0.77	N/A	Pass
-	0.38	14.5	Pass
60 l/s Extract Fan	0.25	29.33	Pass
20 l/s Extract Fan	0.83	26	Pass
-	0.53	N/A	Pass
-	0.73	N/A	Pass
-	0.41	15.33	Pass
70 l/s Extract Fan	0.23	28.83	Pass
25 l/s Extract Fan	0.8	28.33	Pass
-	0.51	N/A	Pass
-	0.76	N/A	Pass
-	0.41	15	Pass
70 l/s Extract Fan	0.22	28	Pass
25 l/s Extract Fan	0.8	28.17	Pass
-	0.53	N/A	Pass

-	0.75	N/A	Pass
-	0.51	16.17	Pass
70 l/s Extract Fan - Window made triple opening casement	0.32	30.83	Pass
30 l/s Extract Fan	0.76	29.5	Pass
-	0.6	17.67	Pass
-	0.6	N/A	Pass
-	1.25	N/A	Pass
-	0.69	21.5	Pass
40 l/s Extract Fan	0.92	24.83	Pass
20 l/s Extract Fan	0.68	29.5	Pass
10 l/s Extract Fan	1.06	31.83	Pass
-	1.32	N/A	Pass
-	1.59	N/A	Pass
-	2.28	N/A	Pass
30 l/s Extract Fan	0.7	28.33	Pass
20 l/s Extract Fan	0.84	27.83	Pass
-	0.79	28.33	Pass
-	0.94	24.17	Pass
-	2.09	N/A	Pass
-	1.33	N/A	Pass
-	0.58	21	Pass
40 l/s Extract Fan	0.68	31.17	Pass
-	0.9	24.83	Pass
-	1.37	N/A	Pass
-	1.07	N/A	Pass
-	0.62	21.67	Pass
40 l/s Extract Fan	0.69	31.67	Pass
-	0.9	25.33	Pass
-	1.43	N/A	Pass
-	1.11	N/A	Pass
-	0.64	21.33	Pass
30 l/s Extract Fan	0.68	28	Pass
-	0.9	25.83	Pass
-	1.37	N/A	Pass
-	1.07	N/A	Pass
-	0.64	21.5	Pass
30 l/s Extract Fan	0.68	27.33	Pass
-	0.9	25.5	Pass
-	1.34	N/A	Pass
-	1.06	N/A	Pass
-	0.69	22.33	Pass
30 l/s Extract Fan	0.69	31	Pass
-	0.91	25.83	Pass
-	1.45	N/A	Pass
-	1.13	N/A	Pass
-	0.61	21.67	Pass
40 l/s Extract Fan	1.09	26.17	Pass

20 l/s Extract Fan	0.7	26.33	Pass
-	0.71	25.67	Pass
-	1.83	N/A	Pass
-	1.43	N/A	Pass
-	1.37	N/A	Pass
20 l/s Extract Fan	1.01	28.83	Pass
20 l/s Extract Fan	1.43	27	Pass
-	0.65	19	Pass
-	0.69	15.83	Pass
-	0.82	15.5	Pass
-	1.13	N/A	Pass
-	1.49	N/A	Pass
-	0.72	16.17	Pass
20 l/s Extract Fan	1.55	30.33	Pass
-	0.94	24.5	Pass
-	0.68	19.33	Pass
-	2.66	N/A	Pass
-	1.17	N/A	Pass
-	1.62	N/A	Pass
20 l/s Extract Fan	0.64	29.17	Pass
10 l/s Extract Fan	0.59	22.67	Pass
30 l/s Extract Fan	0.86	30.53	Pass
40 l/s Extract Fan	0.95	31.67	Pass
40 l/s Extract Fan	1.33	28.5	Pass
-	1.82	N/A	Pass
-	0.7	N/A	Pass
-	0.96	24.83	Pass
-	0.56	18	Pass
-	0.61	N/A	Pass
-	1.28	N/A	Pass
30 l/s Extract Fan	0.98	29	Pass
50 l/s Extract Fan	0.98	31.17	Pass
30 l/s Extract Fan	0.58	23	Pass
-	1.18	N/A	Pass
-	1.18	N/A	Pass
-	0.59	22	Pass
-	1.27	31	Pass
50 l/s Extract Fan	1.11	31.67	Pass
40 l/s Extract Fan	0.9	30.5	Pass
-	1.68	N/A	Pass
-	1.55	N/A	Pass
-	1.14	N/A	Pass
-	0.58	24	Pass
40 l/s Extract Fan	0.96	31.33	Pass
50 l/s Extract Fan	0.71	28.33	Pass
40 l/s Extract Fan	0.81	29	Pass
-	1.4	N/A	Pass

-	1.77	N/A	Pass
-	1.14	N/A	Pass
50 l/s Extract Fan	0.62	27.33	Pass
-	1.26	21.5	Pass
-	1.3	22.17	Pass
Window made double opening casement - All glazing requires 0.38 G-value	2.66	N/A	Pass
-	1.05	N/A	Pass
-	0.58	20.67	Pass
40 l/s Extract Fan	1.07	26	Pass
20 l/s Extract Fan	0.67	26.67	Pass
-	0.71	26	Pass
-	1.75	N/A	Pass
-	1.49	N/A	Pass
-	1.26	N/A	Pass
-	0.96	22.17	Pass
40 l/s Extract Fan	1.57	29	Pass
40 l/s Extract Fan	0.91	27.83	Pass
-	0.78	21.5	Pass
-	2.3	N/A	Pass
-	1.14	N/A	Pass
-	1.84	N/A	Pass
-	1.16	18.67	Pass
50 l/s Extract Fan	1.2	31.83	Pass
-	0.8	23.5	Pass
-	1.17	N/A	Pass
-	2.07	N/A	Pass
-	1.11	18.83	Pass
50 l/s Extract Fan	1.4	30.67	Pass
-	0.96	22.33	Pass
-	1.28	N/A	Pass
-	2.28	N/A	Pass
-	1.09	18.33	Pass
50 l/s Extract Fan	1.17	30.83	Pass
-	0.77	21.83	Pass
-	1.14	N/A	Pass
-	2.1	N/A	Pass
-	0.58	24.67	Pass
60 l/s Extract Fan	1.33	29.5	Pass
50 l/s Extract Fan	1.08	30	Pass
40 l/s Extract Fan	0.88	29.17	Pass
-	1.75	N/A	Pass
-	1.54	N/A	Pass
-	1.19	N/A	Pass
60 l/s Extract Fan	0.52	29.5	Pass
-	0.6	21.17	Pass
-	0.63	21	Pass
-	2.07	N/A	Pass

-	0.78	N/A	Pass
60 l/s Extract Fan	0.52	29.33	Pass
-	0.6	21.17	Pass
-	0.65	20.83	Pass
-	2.1	N/A	Pass
-	0.77	N/A	Pass
60 l/s Extract Fan	2.14	31.17	Pass
50 l/s Extract Fan	0.9	31.33	Pass
50 l/s Extract Fan	0.6	26.17	Pass
-	2.71	N/A	Pass
60 l/s Extract Fan	2.29	31.83	Pass
60 l/s Extract Fan	0.76	27.67	Pass
50 l/s Extract Fan	0.87	28.17	Pass
Patio requires 0.4 G-value	2.26	N/A	Pass
70 l/s Extract Fan	2.22	31.5	Pass
60 l/s Extract Fan	0.7	27.33	Pass
50 l/s Extract Fan	0.82	28.67	Pass
-	2.43	N/A	Pass
80 l/s Extract Fan	2.15	30.67	Pass
60 l/s Extract Fan	0.79	29.67	Pass
50 l/s Extract Fan	0.9	30.5	Pass
Patio requires 0.4 G-value	2.75	N/A	Pass
80 l/s Extract Fan	2.02	30.67	Pass
50 l/s Extract Fan	0.82	31.83	Pass
50 l/s Extract Fan	0.81	30.17	Pass
Patio requires 0.4 G-value	2.73	N/A	Pass