**From:** Lee.Money
**Sent:** 04 January 2024 14:08
**To:** Hannah.Darley
**Subject:** RE: Planning Application Consultation - DC/23/2294 Storrington Lawn Tennis Club Greyfriars Lane Storrington EH response

Hi Hannah

There are no objections in principle to this application.

However, given immediate proximity to adjoining residential properties and the location on the edge of the Storrington it is important that the lighting scheme is managed to avoid obtrusive light impacts. LED lighting can subjectively appear much brighter due to the different colour temperature and intensity compared to the existing lighting. If the application is approved the conditions below should be applied. The council's ecology consultant may also have recommendations regarding the lighting impacts on foraging bats etc.

1. Prior to commencement of development a lighting scheme, including a schedule of luminaires to be used, must be submitted for the approval of the Local Planning Authority in accordance with the Institute of Lighting Professional's Guidance notes for the reduction of obtrusive light. The scheme must be designed by a suitably qualified person in accordance with the recommendations for environmental zone E2 in the ILP document "Guidance Notes for the Reduction of Obtrusive Light" reference GN01-21.

2. Before commencement of operation of the approved lighting scheme the applicant shall appoint a suitably qualified member of the institute of lighting professionals (ILP) to validate that the lighting scheme as installed conforms to the recommendations for environmental zone E2 in the ILP document "Guidance Notes for the Reduction of Obtrusive Light" reference GN01-21. The validation report shall be submitted to and approved by the local planning authority and the approved details and attenuation measures shall be permanently retained and maintained in working order for the duration of the use and their operation.

Regards

lee

Lee Money
Team Leader Environmental Protection
Telephone: 01403 215410 |
07879481032
Email:Lee.Money@horsham.gov.uk
Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL
Telephone: 01403 215100 (calls may be recorded) www.horsham.gov.uk Chief Executive: Jane Eaton

**Lee Money**
Team Leader Environmental Protection

**Telephone:** 01403 215410 | 07879481032
**Email:** Lee.Money@horsham.gov.uk





**Horsham District Council, Parkside, Chart Way, Horsham, West Sussex RH12 1RL**
Telephone: 01403 215100 (calls may be recorded)  www.horsham.gov.uk  Chief Executive: Jane Eaton

-----Original Message-----
From: planning@horsham.gov.uk <planning@horsham.gov.uk>
Sent: 29 December 2023 11:18
To: eh.planningconsultation <eh.planningconsultation@horsham.gov.uk>; Gareth.Jones <Gareth.Jones@horsham.gov.uk>
Subject: Planning Application Consultation - DC/23/2294

Please see the attached consultation letter from Horsham District Council Re:DC/23/2294