

Sam.Nye

Subject: DISC/26/0100

From: Delta Tech
Sent: 07 May 2026 11:27
To: Sam.Nye
Subject: Re: DISC/26/0100

Good Morning Sam

Thank you for your email.

I have received the following information and the points raised.

- I have attached below a screenshot of the carbon filter as requested with relevant information.
- The dwell time would be between 0.2-0.5 seconds
- The pre-filter would normally be a panel or bag with a minimum performance of EU3 to Eurovent 4/5
- Its confirmed the stack termination as proposed will offer a non-impeded vertical discharge without further restrictions etc.

I look forward to hearing from you soon and please don't hesitate to contact me if you have any questions or require additional information, even changes which we can implement very quickly.

Kind regards

Delta Tech



Sitesafe 3 x PA240824

Size	594 x 594 x 597
Gross Weight	53.85Kg
Carbon Weight	50Kg
Rated Airflow	3600m ³ /hr*
Pressure Drop	120Pa

|