[redacted]

From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 14 August 2026 12:12
To: Planning
Subject: Discharge Condition 8 - Fire Hydrants - DISC/26/0231 Land North West of Junipers Harbolets Road West Chiltington West Sussex

Categories: Consultations

FAO: Shazia Penne

Dear Shazia,

Providing the fire hydrant (FH) indicated on the plan submitted for planning consultation No. DISC/26/0231 is in place and ready for use prior to any occupation of any dwellings, the condition will be met and can be discharged. Unfortunately, on too many occasions West Sussex Fire & Rescue Service (WSFRS) are not informed fire hydrants are in place and ready for use prior to dwellings being occupied, which then increases the risk to life and property in the event of a fire occurring. So, please ensure WSFRS are informed when FHs are ready for use

Regards
Ian

Ian Stocks
Water & Access Manager - Protection
West Sussex Fire & Rescue Service
[redacted]
Web www.westsussex.gov.uk/fire
Email frs.waterandaccess@westsussex.gov.uk
Bognor Regis Fire Station Fire Station, West Meads Drive, West S

LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.