Horsham District Council

Lombaard
Purple Pepper Partnership Ltd
Dalnton House
60 Windsor Avenue
Wimbledon
London
SW192RR

Our ref:	DISC/24/0151
Your ref:	Ransoms RWH Conditions 7 and 10
Email:	planning@horsham.gov.uk
Direct Line:	01403 215238
If Calling Please ask for:	Nicola Pettifer
Date:	19th September 2024

Dear Sir/Madam,

Town and Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure England) Order 2015

Approval of details reserved by conditions 6, 7 and 10 to approved application DC/22/1059

Ransoms Station Road Pulborough West Sussex

The Authority has considered your application, and I can confirm that the submitted information is **NOT** acceptable pursuant to the following condition(s):

6. **Pre-Commencement Condition:**: Notwithstanding the Environmental Noise Assessment (submitted 15.05.2023), no development above ground floor slab level shall commence until an acceptable scheme for sound attenuation against external noise has been submitted to and approved by the Local Planning Authority. The approved sound attenuation works shall be completed before the dwellings are occupied and be retained thereafter

   Reason: As this matter is fundamental in the interests of residential amenities by ensuring an acceptable noise level for the occupants of the development in accordance with Policy 33 of the Horsham District Planning Framework (2015).

7. **Pre-Commencement Condition:** No development above ground floor slab level shall commence until full details of the water efficiency measures and rainwater harvesting system, as required by the approved water neutrality strategy (V22Aug22) have been submitted to and approved in writing by the Local Planning Authority. The rainwater harvesting tank shall be sized so as to provide 35+ day drought tolerance capacity. The agreed measures shall be implemented in accordance with the approved details prior to first use of the development hereby approved, and shall be retained, operated and maintained at all times thereafter.

   Reason: To ensure the development is water neutral to avoid an adverse impact on the Arun Valley SACSPA and Ramsar sites in accordance with Policy 31 of the Horsham District Planning Framework (2015), Paragraphs 186 and 187 of the National Planning Policy Framework (2021), its duties under the Conservation of Habitats and Species Regulations 2017 (as amended), and s40 of the NERC Act 2006 (Priority habitats & species).

10. **Pre-Commencement (Slab Level) Condition:** No development above ground floor slab level shall commence until a management and maintenance plan for the rainwater harvesting system has been submitted to and approved in writing by the Local Planning Authority. The management and maintenance plan shall include the following details:

- The sampling regime and parameters etc, recognising that the sampling will need to be undertaken a DWI certified sampler and analysed by a UKAS accredited lab.
- Detail on how any failure of any samples will be investigated and managed.
- Details, including a plan or schematic, showing the supply - storage tanks, treatment etc, and means to record the total water consumption of each unit
- Detail on what type of treatment that will be installed on the supply with information clearly indicating that it is appropriate for the amount of water being used.
- Detail on how the treatment system, pipework, tanks etc will be cleaned and maintained and who will maintain them for the lifetime of the development. This should include any re-activation of the system after it has been out of use due to lack of rainfall/use.
- The completion and sharing of the Regulation 6 risk assessment by a suitably competent person (as required by the Private Water Supply (England) Regulations 2016) prior to the water supply being put into use.
- Detail on the continuity of supply during dry periods extending beyond 35 days.
- Arrangements for keeping written records of all sampling, results of analysis, inspection, cleaning, and maintenance.
- Details of contingency plans to ensure any failure's or reported concerns with the supply are investigated and rectified as soon as possible, including timeframes. This should include notification of the investigation and corrective actions to the local authority

The management and maintenance plan shall be operated in full at all times. No alterations or revisions to the approved management plan shall be implemented without the written approval of the Local Planning Authority.

Reason: To ensure the development is water neutral to avoid an adverse impact on the Arun Valley SACSPA and Ramsar sites in accordance with Policy 31 of the Horsham District Planning Framework (2015), Paragraphs 186 and 187 of the National Planning Policy Framework (2021), its duties under the Conservation of Habitats and Species Regulations 2017 (as amended), and s40 of the NERC Act 2006 (Priority habitats & species).

This letter constitutes a legal document which should be regarded as an addendum to the original planning application.

If you have any queries or require further information, please do not hesitate to contact the Case Officer.

Yours faithfully



Emma Parkes
Head of Development and Building Control

ADDITIONAL INFORMATION

Right of Appeals
If you are aggrieved by the decision to refuse permission for the proposed development then you can appeal to the Secretary of State under Section 78 of the Town and Country Planning Act 1990.

You must appeal within 12 weeks of the date of the decision notice for a householder application or 'minor commercial' (shop front) development, and within 6 months for other types of planning applications. There are different timescale – usually 28 days – if an enforcement notice is/has been served for the same (or very similar) land and development. Please note, only the applicant possesses the right of appeal.

Appeals can be made online at: https://www.gov.uk/planning-inspectorate. If you are unable to access the online appeal form, please contact the Planning Inspectorate to obtain a paper copy of the appeal form on tel: 0303 444 5000.

The Secretary of State can allow a longer period for giving notice of an appeal but will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.

The Secretary of State need not consider an appeal if it seems to the Secretary of State that the local planning authority could not have granted planning permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements, to the provisions of any development order and to any directions given under a development order.

If you intend to submit an appeal that you would like examined by inquiry then you must notify the Local Planning Authority and Planning Inspectorate (inquiryappeals@planninginspectorate.gov.uk) at least 10 days before submitting the appeal. Further details are at https://www.gov.uk/government/collections/casework-dealt-with-by-inquiries.