From: FRS Water and Access <FRSWaterandAccess@westsussex.gov.uk>
Sent: 26 July 2024 12:18
To: Planning
Subject: Planning consultation - DC/24/0836 Butlers Ghyll Farm Pollards Way Southwater West Sussex RH13 9AQ

Categories: Consultations

FAO: Bethan Tinning

Dear Bethan,

Having viewed the plans for the planning application no DC/24/0836 for the alterations to existing building to create new offices, the nearest fire hydrant for the supply of water for firefighting is 980 metres away, 8900 metres further than the 90-metre distance required for a commercial premises. If an alternative supply of water for firefighting is to be considered it will need to conform with the details identified in Approved Document–B (AD-B) Volume 2: B5 section 16 and agreed with West Sussex Fire & Rescue Service.

Regards

Ian

[redacted]
Bognor Regis Fire Station Fire Station, West Meads Drive, West Sussex, PO19 1BD

My pronouns are he/him/his
Click here to find out why we use pronouns in our signatures



LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.